Quarterly Operations Report Second Quarter 2019

Groundwater Treatment Plant GM-38 Area Groundwater Remediation Naval Weapons Industrial Reserve Plant Bethpage, New York

Contract No. N40085-16-D-2288 Contract Task Order No. 0005

October 2019

Prepared for:



Naval Facilities Engineering Command Mid-Atlantic 9324 Virginia Avenue Norfolk, VA 23511

Prepared by:



KOMAN Government Solutions, LLC 180 Gordon Drive, Suite 110 Exton, Pennsylvania 19341 (610) 363-3000

Quarterly Operations Report Second Quarter 2019

Groundwater Treatment Plant GM-38 Area Groundwater Remediation Naval Weapons Industrial Reserve Plant Bethpage, New York

Contract No. N40085-16-D-2288 Contract Task Order No. 0005

October 2019

Prepared for:

Naval Facilities Engineering Command Mid-Atlantic 9324 Virginia Avenue Norfolk, VA 23511



fatish Schule	10/17/2019
Patrick Schauble	Date
Program Manager	

Robert G. Gregory Date

Project Manager

TABLE OF CONTENTS

1.0	INTF	RODUCTION	1- 1
		BackgroundBWTP Overview	
2.0	GWI	TP OPERATIONS AND MAINTENANCE	2- 1
		Youtine Maintenance Activities	
3.0	GWI	TP MONITORING	3- 1
	3.2 A	Frocess Water Quality Monitoring Air Quality Monitoring Groundwater Quality Monitoring Groundwater Quality Results Groundwater Concentration Trends	3-1 3-2 3-3
4.0	CON	CLUSIONS AND RECOMMENDATIONS	4-]
5.0	REF	ERENCES	5- 1
<u>TA</u>]	BLES		
TAE	BLE 1	Discharge Monitoring Results – Second Quarter 2019	
TAE	BLE 2	Air Sampling Results – Second Quarter 2019	
TAE	BLE 3	Stack Emissions – Second Quarter 2019	
TAE	BLE 4	Groundwater Level Measurements – Second Quarter 2019	
FIC	<u>GURES</u>		
FIG	URE 1	Site Map	
FIG	URE 2	Process Flow Diagram	
FIG	URE 3	GM-38 Area Site Map	
FIG	URE 4	Second Quarter 2019 Groundwater Analytical Map – Select VOC Concentration	ons
FIG	URE 5	Groundwater Concentrations Trends of Select VOCs – RW-1	
FIG	URE 6a	Groundwater Concentrations Trends of Select VOCs – RW-3	
FIG	URE 6b	Groundwater Concentrations Trends of PCE and cis-1,2-DCE – RW-3	



APPENDICES

APPENDIX A NYSDEC Effluent Limitations and Monitoring Requirements and April 2019 – June 2019 DMRs

APPENDIX B NYSDEC Air Discharge Limit Documentation

APPENDIX C Field Logs – Second Quarter 2019



Acronyms and Abbreviations

AOP Advanced Oxidation Process

ARAR Applicable or Relevant and Appropriate Requirement

AS air stripper

ASE air stripper effluent
BFE bag filter effluent

bgs below ground surface

CERCLA Comprehensive Environmental Response Compensation and Liability Act

DAR Division of Air Resources

DCA dichloroethane
DCE dichloroethene

DMR Discharge Monitoring Report

DO dissolved oxygen

DoD Department of Defense

DTW depth to water

EB equipment rinsate blank

ECL Environmental Conservation Law

ELAP Environmental Laboratory Accreditation Program

GOCO Government Owned Contractor Operated

gpm gallon per minute

GWTP groundwater treatment plant
HMI human-machine interface

IRP Installation Restoration Program

KGS KOMAN Government Solutions, LLC

lb pound

LGAC liquid-phase granular activated carbon MS/MSD matrix spike/matrix spike duplicate

NAVFAC Naval Facilities Engineering Command Mid-Atlantic

Navy U.S. Department of the Navy

NELAC National Environmental Accreditation Conference

NG Northrop Grumman

NWIRP Naval Weapons Industrial Reserve Plant

NYSDEC New York State Department of Environmental Conservation

NYSDOH New York State Department of Health



O&M Operation and Maintenance
ORP oxidation reduction potential

OU operable unit

PCE tetrachloroethene

PLC programmable logic controller
QA/QC quality assurance / quality control

ROD Record of Decision

RPD relative percent difference SC standard conductivity

SCADA Supervisory Control and Data Acquisition

scfm standard cubic feet per minute

SPDES Storm Pollution Discharge Elimination System

TB trip blank

TCE trichloroethene
TE treated effluent

TIC tentatively identified compound

TSS total suspended solids
TtEC Tetra Tech EC, Inc.

USEPA U.S. Environmental Protection Agency

VC vinyl chloride

VGAC vapor–phase granular activated carbon

VOC volatile organic compound



1.0 INTRODUCTION

KOMAN Government Solutions, LLC (KGS) has prepared this Quarterly Operations Report for the GM-38 Area Groundwater Treatment Plant (GWTP) at the Naval Weapons Industrial Reserve Plant (NWIRP) in Bethpage, New York. This report has been prepared for the U.S. Department of the Navy (Navy), Naval Facilities Engineering Command (NAVFAC), Mid-Atlantic, under Contract No. N40085-16-D-2288, Contract Task Order No. 0005. This Second Quarter 2019 Operations Report details activities that occurred from April to June 2019. Data was collected and operational activities were performed by KGS in accordance with the following documents:

- Final Operation, Maintenance & Monitoring Plan for Groundwater Treatment Plant GM-38 Area Groundwater Remediation, Naval Weapons Industrial Reserve Plant, Bethpage, New York prepared by Tetra Tech EC, Inc. (TtEC) in 2010, hereafter referred to as the "O&M Manual."
- Final Sampling and Analysis Plan (Field Sampling Plan and Quality Assurance Project Plan), UFP-SAP for Operations, Maintenance, and Monitoring of the Groundwater Treatment Plant, GM-38 Area, Naval Weapons Industrial Reserve Plant, Bethpage, New York prepared by TtEC in 2010.

1.1 Background

NWIRP Bethpage is located in east central Nassau County, Long Island, New York, approximately 30 miles east of New York City (**Figure 1**) and is currently listed by New York State Department of Environmental Conservation (NYSDEC) as an "inactive hazardous waste site" (#1-30-003B). In the late 1990s, the Navy's property totaled approximately 109.5 acres and was a Government Owned Contractor-Operated (GOCO) facility that was operated by Northrop Grumman (NG) until September 1998. NWIRP Bethpage was bordered on the north, west, and south by property owned, or formerly owned, by NG that covered approximately 550 acres, and on the east by a residential neighborhood.

The GM-38 Area refers to a cluster of monitoring wells installed in the 1990s by NG. The GM-38 Area is approximately 8,500 feet south, southeast and hydraulically downgradient of NWIRP Bethpage. The GWTP is located within a utility easement with a street address of 100 Broadway, Bethpage, NY.

The "hot spot" cleanup remedy for the GM-38 Area groundwater was originally set forth in Record of Decision (ROD) documents for Operable Unit 2 (OU 2) Groundwater for the NG and NWIRP Sites (New York State Registry Site Numbers 1-30-003A & 1-30-003B, respectively) issued by NYSDEC Division of Environmental Remediation in March 2001 and for the NWIRP Bethpage Site by NAVFAC in April 2003 (Revision 1). The selected remedy was chosen in accordance with the New York State Environmental Conservation Law (ECL) and the Navy's Installation Restoration Program (IRP). It is also consistent with the Comprehensive Environmental Response Compensation and Liability Act (CERCLA), as amended, 42 U.S.C. §§ 9601-9675.



1.2 **GWTP Overview**

Currently, groundwater is extracted from recovery wells RW-1 and RW-3 (pumping at RW-3 was suspended from July 2015 to June 2018 as described below) and treated in the GWTP. The treatment process consists of flow equalization, air stripping and vapor-phase carbon treatment, bag filtration, and liquid-phase carbon treatment. Though the GWTP was originally equipped with a pH adjustment system utilizing sodium hydroxide, it has since been determined that pH adjustment is not necessary, and the equipment has been taken off-line and sodium hydroxide sent off site for beneficial reuse. A process flow diagram is presented as **Figure 2**. The treated water is either re-injected into injection well IW-1 or discharged into the Nassau County Recharge Basin #495. Under CERCLA, the Navy is required to meet the effluent requirement in the NYSDEC's Storm Pollution Discharge Elimination System (SPDES) Equivalent Application as an Applicable or Relevant and Appropriate Requirement (ARAR).

The GWTP was designed to operate at an average flow rate of 1,100 gallons per minute (gpm) (800 gpm from RW-1 and 300 gpm from RW-3), as measured by the average discharge flow rate. It was determined that this flow rate would be necessary to effectively contain the higher concentration of contamination in the GM-38 Area groundwater. Volatile Organic Compounds (VOCs) in the influent groundwater consist of trichloroethene (TCE), tetrachloroethene (PCE), vinyl chloride (VC), cis-1,2-dichloroethene (cis-1,2-DCE), 1,2-dichloroethane (1,2-DCA), benzene, toluene, and total xylenes.

The air stripper (AS) is a structural aluminum tower that is packed with 3.5-inch diameter polypropylene Jaeger Tripack. Groundwater is pumped to the air stripper distribution port and sprayed over the column of Jaeger Tripack at a flow rate of approximately 1,100 gpm. Previously, 100 gpm of recirculated water was also rerouted through the AS, but as of October 2010, recirculation was no longer deemed necessary to the operation of the system. An induced draft countercurrent flow of air enters the air stripper below the base of the packing material at a rate of 8,000 standard cubic feet per minute (scfm). The large surface area of the packing material allows for a mass transfer of the VOCs from the groundwater into the air stream. The VOCs in the off-gas, except for VC, are removed via two 20,000-pound (lb) vapor phase granular activated carbon (VGAC) units (VGAC-1 and VGAC-2). VC is oxidized by a 20,000-lb vessel containing zeolite impregnated with potassium permanganate (VGAC-3) into potassium chloride and carbon dioxide. The potassium chloride remains in the pore structure of the zeolite substrate. The treated off-gas is discharged from the stack.

Water treated by the air stripper is subsequently processed through three 8,000-lb liquid phase granular activated carbon (LGAC) units in parallel prior to discharge in the recovery basin (or injection well, if necessary).

The GWTP is controlled by a programmable logic controller (PLC)-based digital and analog control system, with instrumentation that monitors pH, pressure, tank level, flow and differential pressure transmitters, water level in recovery wells, and motor operational status. The information in the PLC is made available to an operator via a human-machine interface (HMI) program. By using this program, the status of the GWTP can be displayed in real time and adjusted, if necessary, by the operator.



A 2014 evaluation of the GM-38 Area, conducted in order to better determine the capture zone of the recovery wells, recommended that use of recovery well RW-3 be discontinued (*Capture Zone Evaluation and Path Forward, GM-38 Area Groundwater Treatment Plant* [Tetra Tech 2014]). The report was sent to NYSDEC in March 2014 and recommended ceasing operation of recovery well RW-3 and increasing the pumping rate of recovery well RW-1. These system modifications would maintain the existing GWTP pumping rate of 1,000 to 1,100 gpm while maintaining the desired capture zone of the GWTP (Tetra Tech 2014). NYSDEC concurred with the implementation of this path forward and associated system modifications on 20 April 2015. On 1 July 2015, in accordance with the approved path forward, recovery well RW-3 was taken off-line. The flowrate of recovery well RW-1 was increased from approximately 800 gpm to approximately 1,000 gpm. Pumping at RW-3 was once again resumed in June 2018 to address persisting VOC concentrations at this well. Pumping rates were adjusted so that approximately 80% of the total groundwater extracted is from RW-1 with the remaining 20% extracted from RW-3.



2.0 GWTP OPERATIONS AND MAINTENANCE

While designed to run completely automated, the GWTP requires regular visits by an operator to record and adjust operational parameters and to perform scheduled maintenance. The GWTP is equipped with telemetry that will alert an on-call operator in the event of a plant shutdown.

2.1 Routine Maintenance Activities

Routine maintenance activities at the GWTP were performed during the operator's visits. These activities include general site inspections, collection of operational data (water and vapor flowrates, differential pressures across the AS, carbon units, bag filter units and blower discharge pressures, tank levels and totalizer readings), measurement of water levels in the recovery wells, adjustment of pump signal settings, collection of vapor and process water samples, changing out of bag filters, switching of lead/lag pump assignments, and preventive maintenance of system equipment.

In addition, the following maintenance tasks were also performed during the Second Quarter:

- On 8 May, the Operator backwashed LGAC #2, the plant was down for 1.2 hours.
- On 19 June, the Operator rotated and greased the pumps and motors.

2.2 Non-routine Maintenance / Site Activities

The following non-routine activities occurred during the Second Quarter:

- On 31 March, the GWTP was down for 8.5 hours from a high sump alarm caused by a leaking pressure gauge inside the plant on influent pump 3A. The pressure gauge was replaced and the plant placed back on line on 1 April.
- On 12 April, Eagle Control was onsite to assess the plant sump level probe and provide an
 estimate for programing a new level probe into the Supervisory Control and Data Acquisition
 (SCADA) system.
- On 17 April, the system was down for approximately 6 hours due to a power outage.
- On 21 May, F&M was on site to troubleshoot the inoperative plant sump pump. The check valve
 was disassembled and the impeller was cleared of debris. The pump was operating properly after
 cleaning.



2-1

3.0 GWTP MONITORING

The intent of the GWTP is to remove contaminant mass and reduce elevated VOC levels to levels similar to those in the surrounding aquifer. It is anticipated that GWTP operation will minimize contaminant impacts on water supply wells and currently unaffected portions of the groundwater aquifer. The GWTP is not intended to remediate groundwater contamination in the local aquifer to non-detectable levels (TtEC 2010). Various process samples (water and vapor) are collected on a monthly basis to monitor GWTP efficiency and to ensure compliance with Federal and State effluent discharge and air emission requirements. In addition, groundwater samples are collected semi-annually to monitor water quality and determine the effectiveness of the remediation activities and monitor the hydraulic containment and capture of impacted groundwater by the recovery wells.

3.1 Process Water Quality Monitoring

Processed groundwater is analyzed to comply with calculations submitted by the Navy and documented in the NYSDEC Water Division SPDES Equivalent Application for the effluent limitations and monitoring requirements. These results are also submitted to NYSDEC on a monthly basis in the form of a Discharge Monitoring Report (DMR). A copy of the current NYSDEC effluent limitations, monitoring constituents, and the reporting forms are included in **Appendix A**.

Monthly aqueous samples are collected from the active recovery well, RW-1, RW-3, and the treated effluent (TE) discharge line. In addition, various intermediary process system samples are collected monthly, consisting of air stripper effluent (ASE), bag filter effluent (BFE), and effluent of each of the three LGAC units (LC1, LC2, and LC3).

The analytical results of monthly process water samples collected during the Second Quarter are presented in **Table 1**. The data demonstrate that all permitted constituents were in compliance with regulatory requirements during the Second Quarter. **Table 1** also summarizes the average monthly flowrates in gallons per minute along with the total volume of water processed during each month of the Second Quarter. Monthly DMRs for the Second Quarter (April – June 2019) are included in **Appendix A**.

3.2 Air Quality Monitoring

Treated off-gas discharged at the stack of the GWTP is subject to emissions limitations. Original discharge goals were derived from calculations submitted by the Navy and approved by the NYSDEC Division of Air Resources (DAR) in July 2009. In November 2011, the Navy submitted an evaluation proposing revised discharge goals, which NYSDEC approved in October 2013. A copy of this documentation is included as **Appendix B**.

While only sampling of the stack emissions is required for NYSDEC compliance, process vapor samples are also collected using 6-L summa canisters at various locations to monitor for breakthrough of the VGAC units. The analytical results of monthly influent and effluent vapor samples as well as midfluent samples (VC12 and VC13) collected during the Second Quarter are presented in **Table 2**. Air emissions calculations using the stack vapor concentrations along with discharge flowrates are presented in **Table 3**.



The calculations demonstrate that all constituents were within the regulatory requirements during the Second Quarter based on the calculated emission rates.

3.3 Groundwater Quality Monitoring

The groundwater monitoring well system at the GM-38 Groundwater Remediation Area consists of fourteen monitoring wells, three recovery wells (RW-1, RW-2, RW-3) and one injection well (IW-1). Groundwater level measurements were collected and are summarized in **Table 4**. Though RW-2 was installed in 2005, a pump was never installed in this well and the well is not operated as a recovery well due to concerns expressed by the Bethpage Water District. As mentioned above, pumping at RW-3 was suspended between July 2015 and June 2018. RW-3 was reactivated on 1 June 2018 to address persistent VOC concentrations at this location. Well locations are depicted on **Figure 3**.

Depth to water (DTW) measurements are collected from twelve of the monitoring wells on a quarterly basis. Prior to 2014, water quality samples were collected from eight of the monitoring wells on a quarterly basis; beginning in 2014, the sample collection frequency was reduced to semi-annually, with sample collection generally in the March and September time-frame. The monitoring network includes well clusters located near the recovery and injection wells as described below and as shown on **Figure 3**. In addition, two wells, GM-38D and GM-38D2, located at the corner of Arthur Avenue and Broadway, are monitored by others.

Descriptions of monitoring well locations are as follows:

Recovery Well 1 (RW-1) Monitoring Wells

The RW-1 cluster consists of three monitoring wells screened between 395 and 435 feet below ground surface (bgs). RW1-MW1 is located approximately 140 feet northwest of RW-1 and RW1-MW2 is located approximately 50 feet north of RW-1. RW1-MW3 is located approximately 400 feet northeast of RW-1, on the eastern side of Seaford Oyster Bay Expressway. All three wells are hydraulically monitored while only RW1-MW1 and RW1-MW3 are also monitored for water quality.

Recovery Well 2 (RW-2) Monitoring Wells

The RW-2 cluster consists of three monitoring wells screened between 470 and 510 feet bgs. RW2-MW1 is located approximately 60 feet northwest of RW-2, RW2-MW2 is located approximately 20 feet west of RW-2, and RW2-MW3 is located approximately 100 feet west of RW-2. All three wells are hydraulically monitored while only RW2-MW1 is monitored for water quality.

Recovery Well 3 (RW-3) Monitoring Wells

The RW-3 cluster consists of four monitoring wells. RW3-MW2 and RW3-MW4 are screened between 475 and 495 feet bgs. RW3-MW1 and RW3-MW3 are screened between 330 and 350 feet bgs and 320 and 340 feet bgs, respectively. RW3-MW1 and RW3-MW2 are located approximately 500 feet west of the GM-38 cluster, at the intersection of Arthur Avenue and Leroy Avenue. RW3-MW3 and RW3-MW4 are located approximately 400 feet north of the intersection of Arthur Avenue and Broadway. All four wells are both hydraulically monitored and monitored for water quality.



3-2

TP-01

TP-01 is screened between 450 and 470 feet bgs and is located approximately 25 feet north of the GWTP building, inside the fenced area. It is hydraulically monitored to observe the change in water levels due to the influence from the pumping rates at the neighboring public water supply well field near the hot spot area and is also monitored for water quality.

Injection Well 1 (IW-1) Monitoring Well

There is one monitoring well associated with injection well IW-1. IW1-MW1 is screened between 20 and 150 feet bgs, is located approximately 20 feet south of IW-1 and is only hydraulically monitored on a quarterly basis.

3.3.1 Groundwater Quality Results

Quarterly groundwater level measurements of the twelve monitoring wells were collected on 30 May 2019. Results are summarized in **Table 4**. A copy of the field log is included in **Appendix C**.

As mentioned above, groundwater samples are only collected semi-annually in the First and Third Quarters; no groundwater samples were collected from the monitoring wells during the Second Quarter 2019. Samples are collected monthly from recovery well RW-1 and RW-3, results of which are summarized in **Table 1**.

3.3.2 Groundwater Concentration Trends

Groundwater analytical results of select VOCs (cis-1,2-DCE, PCE, TCE, and VC) for the recovery wells during the Second Quarter Monitoring Event are presented graphically as **Figure 4.** Additionally, concentration trends of select VOCs (cis-1,2-DCE, TCE, and PCE, as well as VC) for RW-1 and RW-3 are presented in **Figures 5** and **Figure 6a and 6b**, respectively and discussed below.

Figure 5 presents concentrations measured at recovery well RW-1. Concentrations of TCE have decreased from initial concentrations in early 2010 (747 μg/L detected in April 2010), remaining below 300 μg/L since the latter half of 2012 and decreasing to a low of 63.1 μg/L in May 2019. Concentrations of cis-1,2-DCE have followed a similar trend, decreasing from a high of 160 μg/L in February 2010 to a low of 4.36 μg/L in March 2019, and remaining below 5.0 μg/ during the Second Quarter 2019. PCE concentrations have also exhibited decreasing trends over time, with concentrations decreasing from 180 μg/L in February 2010 to a low of 16.0 μg/L in May 2019. Concentrations of VC have decreased below initial concentrations in 2010. After reaching a maximum concentration of 61 μg/L in February 2010, VC concentrations have remained below 1.0 μg/L since June 2013. Vinyl chloride was not detected during the Second Quarter 2019.

Figure 6a-6b presents concentrations measured at recovery well RW-3. Concentrations of TCE have decreased from initial concentrations in February 2010 (660 μ g/L), remaining below 300 μ g/L from the latter half of 2012 through the Third Quarter 2015. RW-3 was taken off-line from 1 July 2015 until 1 June 2018, which may have contributed to the increased concentrations in 2016. However, since March 2016, TCE concentrations have decreased from 371 μ g/L down to a low of 120 μ g/L detected in March 2018 but have increased slightly to an average concertation of 151 μ g/L during the Second Quarter 2019.



Concentrations of cis-1,2-DCE have consistently remained below 4.0 μ g/L, and below 2.0 μ g/L since September 2013, though the concentration increased slightly to 2.4 μ g/L in March 2016, then decreased again below 2.0 μ g/L since June 2018. PCE has only been detected infrequently at this location, with the most recent detection of 0.25 J μ g/L in June 2019. Vinyl chloride has not been detected during any monitoring event.



4.0 CONCLUSIONS AND RECOMMENDATIONS

The intent of the groundwater treatment system at GM-38 is to remove mass and reduce elevated VOC concentrations to levels similar to those in the surrounding aquifer, and in doing so minimize the impacts on downgradient water supply wells and currently unaffected portions of the aquifer. Based on the removal of VOCs by the GWTP and decreasing contaminant concentration trends observed in the recovery wells and several of the monitoring wells, progress toward these goals is apparent. Based on the concentrations in the groundwater wells, the GWTP should continue to be operated. The groundwater sampling frequency for the eight monitoring wells has been reduced to semi-annually in accordance with the O&M Manual. Water levels for the 12 monitoring wells will continue to be monitored on a quarterly basis.




5.0 REFERENCES

Tetra Tech, Inc. (Tetra Tech). 2014. *Capture Zone Evaluation and Path Forward, GM-38 Area Groundwater Treatment Plant, Naval Weapons Industrial Reserve Plant, Bethpage, New York.* March.

Tetra Tech EC, Inc. (TtEC). 2010. Final Operation, Maintenance & Monitoring Plan for Groundwater Treatment Plant GM-38 Area Groundwater Remediation, Naval Weapons Industrial Reserve Plant, Bethpage, New York. April.

Tetra Tech EC, Inc. (TtEC). 2010a. Final Sampling and Analysis Plan (Field Sampling Plan and Quality Assurance Project Plan), UFP-SAP for Operations, Maintenance, and Monitoring of the Groundwater Treatment Plant, GM-38 Area, Naval Weapons Industrial Reserve Plant, Bethpage, New York. September.





GM-38 Area Groundwater Remediation Groundwater Treatment Plant

Naval Weapons Industrial Reserve Plant - Bethpage, NY
Discharge Monitoring Results
Second Quarter 2019

SPDES Parameters	Daily Maximum Goal	Units		April 2019								
Process Stream			RW-1	RW-3	Combined Influent	Air Stripper Effluent (ASE)	Bag Filter Effluent (BFE)	Liquid Carbon 1 Effluent (LC1)	Liquid Carbon 2 Effluent (LC2)	Liquid Carbon 3 Effluent (LC3)	Treated Effluent (TE)	Treated Effluent (TE) Duplicate
Well Depth		ft	445	530	NA	NA	NA	NA	NA	NA	NA	NA
Screened Interval		ft	335-395 410-430	392-412 442-504	NA	NA	NA	NA	NA	NA	NA	NA
Sampling Date							4/3,	/19				
Average Flowrate	1100	GPM	637	169	806	NR	826	NR	NR	NR	855	NR
Total Flow		gallons	28,015,378	7,432,355	35,447,734	NR	36,345,616	NR	NR	NR	37,628,461	NR
pH	5.5 - 8.5	SU	5.14	5.32	5.18	6.26	6.29	6.33	6.33	6.34	6.33	6.34
Chloroform	5	μg/L	0.335 J	0.289 J	0.33 J	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)
1,1-Dichloroethane	5	μg/L	1.14 J	1.68 J	1.25 J	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)
1,2-Dichloroethane	0.6	μg/L	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)
1,1-Dichloroethene	5	μg/L	0.876 J	0.987 J	0.899 J	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)
cis 1,2-Dichloroethene	5	μg/L	4.49 J	1.22 J	3.80 J	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)
trans 1,2-Dichloroethene	5	μg/L	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)
Tetrachloroethene	5	μg/L	20.8	0.229 J	16.49	0.232 J	0.230 J	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)
1,1,1-Trichloroethene	5	μg/L	0.576 J	0.547 J	0.570 J	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)
Trichloroethene	5	μg/L	77.3	168	96.3	1.63 J	1.19 J	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)
1,1,2-Trichlorotrifluoroethane	5	μg/L	ND (1.0)	0.718 J	0.15 J	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)
Vinyl Chloride	2	μg/L	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)
1,4-Dioxane		μg/L	2.1	4.8	2.67	NS	NS	NS	NS	NS	NS	NS
Mercury	0.00025	mg/L	ND (0.00010)	ND (0.00010)	ND (0.00010)	ND (0.00010)	0.0001 J	0.0001 J	0.00008 J	ND (0.00010)	ND (0.00010)	ND (0.00010)
Total Suspended Solids (TSS)	NA	mg/L	ND (1.0)	1.5	0.3	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)

GM-38 Area Groundwater Remediation Groundwater Treatment Plant Naval Weapons Industrial Reserve Plant - Bethpage, NY Discharge Monitoring Results Second Quarter 2019

SPDES Parameters	Daily Maximum Goal	Units		May 2019								
Process Stream			RW-1	RW-3	Combined Influent	Air Stripper Effluent (ASE)	Bag Filter Effluent (BFE)	Liquid Carbon 1 Effluent (LC1)	Liquid Carbon 2 Effluent (LC2)	Liquid Carbon 3 Effluent (LC3)	Treated Effluent (TE)	Treated Effluent (TE) Duplicate
Well Depth		ft	445	530	NA	NA	NA	NA	NA	NA	NA	NA
Screened Interval		ft	335-395 410-430	392-412 442-504	NA	NA	NA	NA	NA	NA	NA	NA
Sampling Date				•			5/2	1/19	•			
Average Flowrate	1100	GPM	659	168	827	NR	818	NR	NR	NR	877	NR
Total Flow		gallons	29,369,700	7,475,300	36,845,000	NR	36,440,500	NR	NR	NR	39,069,200	NR
рН	5.5 - 8.5	SU	5.34	5.07	5.29	6.37	6.39	6.39	6.39	6.40	6.39	6.40
Chloroform	5	μg/L	0.310 J	0.300 J	0.31 J	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)
1,1-Dichloroethane	5	μg/L	1.45 J	2.12 J	1.59 J	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)
1,2-Dichloroethane	0.6	μg/L	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)
1,1-Dichloroethene	5	μg/L	0.880 J	1.11 J	0.927 J	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)
cis 1,2-Dichloroethene	5	μg/L	4.89 J	1.21 J	4.14 J	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)
trans 1,2-Dichloroethene	5	μg/L	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)
Tetrachloroethene	5	μg/L	16.0	0.250 J	12.80	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)
1,1,1-Trichloroethene	5	μg/L	0.610 J	0.550 J	0.598 J	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)
Trichloroethene	5	μg/L	63.1	143	79.3	1.26 J	1.01 J	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)
1,1,2-Trichlorotrifluoroethane	5	μg/L	ND (1.0)	0.800 J	0.16 J	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)
Vinyl Chloride	2	μg/L	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)
1,4-Dioxane		μg/L	2.1	4.5	2.59	NS	NS	NS	NS	NS	2.6	NS
Mercury	0.00025	mg/L	ND (0.00010)	ND (0.00010)	ND (0.00010)	ND (0.00010)	ND (0.00010)	ND (0.00010)	ND (0.00010)	ND (0.00010)	ND (0.00010)	ND (0.00010)
Total Suspended Solids (TSS)	NA	mg/L	ND (1.0)	5.8	1.2	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)

GM-38 Area Groundwater Remediation Groundwater Treatment Plant Naval Weapons Industrial Reserve Plant - Bethpage, NY

Discharge Monitoring Results Second Quarter 2019

SPDES Parameters	Daily Maximum Goal	Units		June 2019								
Process Stream			RW-1	RW-3	Combined Influent	Air Stripper Effluent (ASE)	Bag Filter Effluent (BFE)	Liquid Carbon 1 Effluent (LC1)	Liquid Carbon 2 Effluent (LC2)	Liquid Carbon 3 Effluent (LC3)	Treated Effluent (TE)	Treated Effluent (TE) Duplicate
Well Depth		ft	445	530	NA	NA	NA	NA	NA	NA	NA	NA
Screened Interval		ft	335-395 410-430	392-412 442-504	NA	NA	NA	NA	NA	NA	NA	NA
Sampling Date				6/3/19								•
Average Flowrate	1100	GPM	658	190	849	NR	833	NR	NR	NR	888	NR
Total Flow		gallons	28,440,905	8,229,550	36,670,454	NR	36,002,680	NR	NR	NR	38,359,733	NR
pH	5.5 - 8.5	SU	5.23	4.99	5.18	5.88	5.91	5.89	5.89	5.90	5.92	5.92
Chloroform	5	μg/L	0.290 J	0.310 J	0.29 J	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)
1,1-Dichloroethane	5	μg/L	1.40 J	2.09 J	1.55 J	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)
1,2-Dichloroethane	0.6	μg/L	0.220 J	ND (1.0)	0.17 J	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)
1,1-Dichloroethene	5	μg/L	0.830 J	0.980 J	0.864 J	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)
cis 1,2-Dichloroethene	5	μg/L	4.41 J	1.15 J	3.68 J	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)
trans 1,2-Dichloroethene	5	μg/L	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)
Tetrachloroethene	5	μg/L	17.8	0.250 J	13.86	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)
1,1,1-Trichloroethene	5	μg/L	0.550 J	0.510 J	0.541 J	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)
Trichloroethene	5	μg/L	65.6	142	82.7	0.940 J	1.00 J	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)
1,1,2-Trichlorotrifluoroethane	5	μg/L	ND (1.0)	0.650 J	0.15 J	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)
Vinyl Chloride	2	μg/L	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)
1,4-Dioxane		μg/L	1.7	4.1	2.24	NS	NS	NS	NS	NS	NS	NS
Mercury	0.00025	mg/L	ND (0.00010)	ND (0.00010)	ND (0.00010)	ND (0.00010)	ND (0.00010)	ND (0.00010)	ND (0.00010)	ND (0.00010)	ND (0.00010)	ND (0.00010)
Total Suspended Solids (TSS)	NA	mg/L	ND (1.0)	6.2	1.4	8.8	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)

Notes:

- J Estimated result between laboratory method detection limit and reporting limit
- NA Not Applicable
- ND Not detected above laboratory method detection limit. Limit of detection (LOD) given in parentheses.
- NS Not Sampled
- gpm gallons per minute
- (1) Wastewater discharge equivalence permit renewed on 18 August 2017. Discharge limits established for 10 years. Chloroform, 1,4-dioxane and 1,1,2-trichlorotrifluoroethane are now monitored under the new permit.

GM-38 Area Groundwater Remediation

Groundwater Treatment Plant

Naval Weapons Industrial Reserve Plant - Bethpage, NY

Air Sampling Results
Second Quarter 2019

DAR Parameters	Discharge Goal ⁽³⁾	Units	April 2019					
Process Stream			Influent (VCI1)	VC12	VC23	Effluent	Effluent Duplicate	
Sampling Date					4/3/19			
Average Flowrate		CFM	NR	NR	NR	9,397	NR	
Total Flow ⁽¹⁾		ft ³	NR	NR	NR	395,981,738	NR	
Total Flow ⁽²⁾		m ³	NR	NR	NR	11,212,954	NR	
1,2-Dichloroethane	NA	μg/m³	2.2 J	2.7 J	ND	ND	ND	
cis 1,2-Dichloroethene	≤ 100,000 ⁽⁴⁾	μg/m³	54	54	88	72	69	
trans 1,2-Dichloroethene	≤ 100,000 ` ′	μg/m³	ND	ND	1.5 J	ND	ND	
1,2-Dichloroethene (total)	≤ 100,000	μg/m³	56	56	90	71	67	
Toluene	NA	μg/m³	0.36 J	ND	ND	ND	ND	
Xylene	NA	μg/m³	ND	ND	ND	ND	ND	
1,1,2-Trichloroethane	NA	μg/m³	ND	ND	ND	ND	ND	
Trichloroethene	≤ 2600	μg/m³	1100	1100	0.86 J	0.62 J	ND	
Vinyl Chloride	≤ 560	μg/m³	1.3 J	ND	0.87 J	ND	0.66 J	
Tetrachloroethene	≤ 5100	μg/m³	180	11	ND	ND	ND	

Notes:

NA - Not applicable

ND - Not detected

NR - Not recorded

SGC - Short-term Guideline Concentration

μg/m³ - micrograms per cubic meter

CFM - cubic feet per minute

DAR - Division of Air Rescources

- (1) Total Flow (ft³) = avg flowrate (cfm) * operational time (min)
- (2) Total Flow (m^3) = total flow (ft^3) * (0.3048^3) m^3/ft^3
- (3) Disharge goal as concurred by NYSDEC's letter dated 10/31/2013.
- (4) Discharge goal is for total 1,2-Dichloroethene.

GM-38 Area Groundwater Remediation

Groundwater Treatment Plant

Naval Weapons Industrial Reserve Plant - Bethpage, NY

Air Sampling Results
Second Quarter 2019

DAR Parameters	Discharge Goal ⁽³⁾	Units	May 2019					
Process Stream			Influent (VCI1)	VC12	VC23	Effluent	Effluent Duplicate	
Sampling Date					5/1/19			
Average Flowrate		CFM	NR	NR	NR	8,972	NR	
Total Flow ⁽¹⁾		ft ³	NR	NR	NR	399,909,108	NR	
Total Flow (2)		m^3	NR	NR	NR	11,324,165	NR	
1,2-Dichloroethane	NA	μg/m³	1.9 J	2.9 J	ND	ND	ND	
cis 1,2-Dichloroethene	≤ 100,000 ⁽⁴⁾	μg/m³	48	52	99	79	83	
trans 1,2-Dichloroethene	≤ 100,000 ` ′	μg/m³	ND	ND	ND	ND	ND	
1,2-Dichloroethene (total)	≤ 100,000	μg/m³	48	52	99	79	83	
Toluene	NA	μg/m³	ND	ND	ND	ND	ND	
Xylene	NA	μg/m³	ND	ND	ND	ND	ND	
1,1,2-Trichloroethane	NA	μg/m³	ND	ND	ND	ND	ND	
Trichloroethene	≤ 2600	μg/m³	1100	1500	2.5 J	1.3 J	ND	
Vinyl Chloride	≤ 560	μg/m³	1.1 J	1.0 J	0.98 J	0.95 J	0.80 J	
Tetrachloroethene	≤ 5100	μg/m³	170	11	ND	ND	ND	

Notes:

NA - Not applicable

ND - Not detected

NR - Not recorded

SGC - Short-term Guideline Concentration

μg/m³ - micrograms per cubic meter

CFM - cubic feet per minute

DAR - Division of Air Rescources

- (1) Total Flow (ft³) = avg flowrate (cfm) * operational time (min)
- (2) Total Flow (m^3) = total flow (ft^3) * (0.3048^3) m^3/ft^3
- (3) Disharge goal as concurred by NYSDEC's letter dated 10/31/2013.
- (4) Discharge goal is for total 1,2-Dichloroethene.

GM-38 Area Groundwater Remediation

Groundwater Treatment Plant

Naval Weapons Industrial Reserve Plant - Bethpage, NY Air Sampling Results

Second Quarter 2019

DAR Parameters	Discharge Goal ⁽³⁾	Units	June 2019					
Process Stream			Influent (VCI1)	VC12	VC23	Effluent	Effluent Duplicate	
Sampling Date					6/3/19			
Average Flowrate		CFM	NR	NR	NR	8,631	NR	
Total Flow ⁽¹⁾		ft ³	NR	NR	NR	372,863,970	NR	
Total Flow ⁽²⁾		m ³	NR	NR	NR	10,558,332	NR	
1,2-Dichloroethane	NA	μg/m³	2.5 J	ND	ND	ND	ND	
cis 1,2-Dichloroethene	≤ 100,000 ⁽⁴⁾	μg/m³	52	50	91	79	75	
trans 1,2-Dichloroethene	≤ 100,000 ` ′	μg/m³	ND	ND	2.0 J	2.1 J	ND	
1,2-Dichloroethene (total)	≤ 100,000	μg/m³	52	50	93	81	75	
Toluene	NA	μg/m³	1.1 J	ND	ND	ND	ND	
Xylene	NA	μg/m³	ND	ND	ND	ND	ND	
1,1,2-Trichloroethane	NA	μg/m³	2.8 J	ND	ND	ND	ND	
Trichloroethene	≤ 2600	μg/m³	1100	2000	0.88 J	8.3	0.78 J	
Vinyl Chloride	≤ 560	μg/m³	1.1 J	1 J	1.1 J	0.89 J	0.65 J	
Tetrachloroethene	≤ 5100	μg/m³	180	10	ND	ND	ND	

Notes:

NA - Not applicable

ND - Not detected

NR - Not recorded

SGC - Short-term Guideline Concentration

μg/m³ - micrograms per cubic meter

CFM - cubic feet per minute

DAR - Division of Air Rescources

- (1) Total Flow (ft³) = avg flowrate (cfm) * operational time (min)
- (2) Total Flow (m^3) = total flow (ft^3) * (0.3048^3) m^3/ft^3
- (3) Disharge goal as concurred by NYSDEC's letter dated 10/31/2013.
- (4) Discharge goal is for total 1,2-Dichloroethene.

GM-38 Area Groundwater Remediation Groundwater Treatment Plant

Naval Weapons Industrial Reserve Plant - Bethpage, NY

Stack Emissions Second Quarter 2019

DAR Parameters	Discharge Goal ⁽¹⁾	Units	April 2019	May 2019	June 2019
Sampling Date			4/3/19	5/1/19	6/3/19
Average Flowrate		CFM	9,397	8,972	8,631
Total Flow		ft ³	395,981,738	399,909,108	372,863,970
Total Flow		m^3	11,212,954	11,324,165	10,558,332
Trichloroethene	0.09	lb/hr	0.00002	0.00004	0.00027
Vinyl Chloride	0.02	lb/hr	0.00000	0.00003	0.00003
1,2 Dichloroethene	11	lb/hr	0.00244	0.00265	0.00262
1,2-Dichloroethane	NA	lb/hr	0.00000	0.00000	0.00000
Toluene	NA	lb/hr	0.00000	0.00000	0.00000
Total Xylene	NA	lb/hr	0.00000	0.00000	0.00000
1,1,2-Trichloroethane	NA	lb/hr	0.00000	0.00000	0.00000
Tetrachloroethene	0.18	lb/hr	0.00000	0.00000	0.00000

Notes:

NA - Not applicable

lb/hr - pounds per hour

DAR - Divison of Air Resources

CFM - Cubic feet per minute

Stack Emissions (lb/hr) = average flowrate (cfm) * $(0.3048^{^3})$ m³/ft³ * conc.(ug/m³) * 1 lb/453592370 ug * 60 min/hr

(1) Discharge goal as concurred by NYSDEC's letter dated 31 October 2013.

GM-38 Area Groundwater Remediation

Groundwater Treatment Plant Naval Weapons Industrial Reserve Plant - Bethpage, NY

Groundwater Level Measurements Second Quarter 2019


Monitoring Well ID	Date	Well Elevation (ft amsl)	Total Depth (ft)	Screen Interval (ft)	Depth to Water (ft)	Groundwater Elevation (ft amsl)
RW1-MW1	05/30/19	85.86	435	395-435	38.42	47.44
RW1-MW2	05/30/19	87.35	435	395-435	41.71	45.64
RW1-MW3	05/30/19	80.34	435	395-435	38.42	41.92
RW2-MW1	05/30/19	90.75	510	470-510	44.04	46.71
RW2-MW2	05/30/19	90.15	510	470-510	42.47	47.68
RW2-MW3	05/30/19	89.75	510	470-510	42.55	47.20
RW3-MW1	05/30/19	92.22	350	330-350	40.19	52.03
RW3-MW2	05/30/19	91.98	495	475-495	43.11	48.87
RW3-MW3	05/30/19	92.98	340	320-340	42.41	50.57
RW3-MW4	05/30/19	92.92	495	475-495	44.17	48.75
TP-01	05/30/19	85.91	470	450-470	40.13	45.78
IW1-MW1	05/30/19	89.41	150	20-150	37.48	51.93
GM38D	NA	91.37	340	320-340	NA	NA
GM382D	NA	91.57	495	475-495	NA	NA


Notes:


amsl - above mean sea level

ft - feet

NA - Not Available









U.S. Navy RAC
Engineering Field Activity, Northeast
GM-38 Area (Offsite)
NWIRP Bethpage
Bethpage, NY

Figure 1 Site Location Map








Figure 5
GM-38 Area Groundwater Remediation
Naval Weapons Industrial Reserve Plant - Bethpage, NY
Groundwater Concentration Trends of Select VOCs

RW1




Figure 6a
GM-38 Area Groundwater Remediation
Naval Weapons Industrial Reserve Plant - Bethpage, NY
Groundwater Concentration Trends of Select VOCs

RW3






Figure 6b
GM-38 Area Groundwater Remediation
Naval Weapons Industrial Reserve Plant - Bethpage, NY
Groundwater Concentration Trends of Select VOCs

RW3



APPENDIX A

NYSDEC EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS AND MONTHLY DMRS





6 May 2019

Mr. Jason Pelton New York State Department of Environmental Conservation Division of Solid & Hazardous Materials 625 Broadway Albany, NY 12233-7252

Subject: GROUNDWATER DISCHARGE MONITORING/AIR EMISSION REPORT

GM-38 AREA, NWIRP BETHPAGE, NY; DER SITE # 1-30-003B-OU 2

APRIL 2019 REPORTING PERIOD

Dear Mr. Pelton:

KOMAN Government Solutions, LLC (KGS) is submitting this monthly monitoring report of the groundwater discharge and air emission results for the Groundwater Treatment Plant (GWTP) located at the Former Naval Weapons Industrial Reserve Plant (NWIRP), Bethpage, NY, GM-38 Area. This report was prepared in accordance with GWTP operational requirements for DER Site # 1-30-003B-OU 2, and the SPDES Permit Equivalent # 13003B.

GWTP operational data from 1 April to 30 April 2019 are presented in Attachment A. In the April reporting period, no significant downtime was recorded for the GM38.

As indicated in Attachment A, all SPDES permitted constituents were in compliance with regulatory guidelines during this reporting period.

Please contact me at 610-400-0622 with any questions or concerns you may have regarding this report.

Sincerely,

KOMAN Government Solutions, LLC

Stephane Roy Project Manager

Attachment A: Groundwater and Air Sampling Results from April 2019

Cc: S. Edwards, NYSDEC

D. Hesler, NYSDEC

C. Haas, NYSDEC Region 1 W. Parish, NYSDEC Region 1

R. Wither, NYSDEC Division of Water

- J. Pilewski, NYSDEC Region 1 Water Engineer
- S. Karpinski, NYSDOH
- J. Lovejoy, NCDH
- L. Thantu, USEPA Region 2
- G. Ennis, Nassau County Department of Public Works
- S. Urban, Nassau County Department of Public Works
- T. Licata, Town of Oyster Bay
- M. Russo, Town of Oyster Bay
- L. Fly, NAVFAC Mid-Atlantic
- B. Murray, NAVFAC Mid-Atlantic RPM
- G. Pearman, NWIRP Bethpage
- GM-38 Copy

ATTACHMENT A GROUNDWATER AND AIR SAMPLING RESULTS APRIL 2019

GM-38 Area Groundwater Remediation Groundwater Treatment Plant

Naval Weapons Industrial Reserve Plant - Bethpage, NY Discharge Monitoring Report April 2019

SPDES Parameters				April 2019 ⁽¹⁾				
Process Stream	Daily Treated Effluent Maximum ⁽¹⁾	Units	RW-1	RW-3 ⁽²⁾	Combined Influent (3) (RW-1 + RW-3)	Treated Effluent		
Well Depth	N/A	ft	445	530	N/A	N/A		
Screened Interval	N/A	ft bgs	335-395 410-430	392-412 442-504	N/A	N/A		
Sampling Date	N/A			4,	/3/19			
Effective Flowrate	1100	GPM	637	169	806	855		
Total Flow	N/A	gallons	28,015,378	7,432,355	35,447,734	37,628,461		
рН	5.5 - 8.5	SU	5.14	5.32	5.18	6.33		
Chloroform	5	μg/L	0.335 J	0.289 J	0.33 J	ND (1.0)		
1,1-Dichloroethane	5	μg/L	1.14 J	1.68 J	1.25 J	ND (1.0)		
1,2-Dichloroethane	0.6	μg/L	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)		
1,1-Dichloroethene	5	μg/L	0.876 J	0.987 J	0.899 J	ND (1.0)		
cis 1,2-Dichloroethene	5	μg/L	4.49 J	1.22 J	3.80 J	ND (1.0)		
trans 1,2-Dichloroethene	5	μg/L	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)		
Tetrachloroethene	5	μg/L	20.8	0.229 J	16.49	ND (1.0)		
1,1,1-Trichloroethane	5	μg/L	0.576 J	0.547 J	0.570 J	ND (1.0)		
Trichloroethene	5	μg/L	77.3	168	96.3	ND (1.0)		
1,1,2-Trichlorotrifluoroethane	5	μg/L	ND (1.0)	0.718 J	0.15 J	ND (1.0)		
Vinyl Chloride	2	μg/L	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)		
1,4-Dioxane		μg/L	2.1	4.8	2.67	NS		
Mercury	0.00025	mg/L	ND (0.00010)	ND (0.00010)	ND (0.00010)	ND (0.00010)		
Total Suspended Solids (TSS)	N/A	mg/L	ND (1.0)	1.5	0.3	ND (1.0)		

Notes:

- J Estimated result between laboratory method detection limit and reporting limit
- D Concentration is a result of a dilution.
- ND Not detected above laboratory method detection limit. Reporting Limit (RL) given in parentheses.
- NR Not Recorded
- N/A Not Applicable
- NS Not Sampled
- (1) Wastewater discharge equivalence permit renewed on 18 August 2017. Discharge limits established for 10 years. Chloroform, 1,4-dioxane and 1,1,2-trichlorotrifluoroethane are now monitored under the new permit.
- (2) Well RW-3 was placed back in operation on 1 June, 2018.
- (3) Influent concentrations presented are the weighted average concentrations of RW-1 and RW-3.

GM-38 Area Groundwater Remediation Groundwater Treatment Plant Naval Weapons Industrial Reserve Plant - Bethpage, NY Air Sampling Results April 2019

DAR Parameters	April 2019			
Process Stream	Units	Discharge Goal ⁽¹⁾	Influent	Effluent
Sampling Date			4,	/3/19
Average Flowrate	CFM	N/A	NR	9,397
Total Flow	ft ³	N/A	NR	395,981,738
Total Flow	m ³	N/A	NR	11,212,954
1,2-Dichloroethane	μg/m³	N/A	2.2 J	ND
cis 1,2-Dichloroethene	μg/m³	≤ 100,000 ⁽²⁾	54	72
trans 1,2-Dichloroethene	μg/m³	≤ 100,000	ND	ND
1,2-Dichloroethene (total)	μg/m³	≤ 100,000	56	71
Toluene	μg/m³	N/A	0.36 J	ND
Total Xylene	μg/m³	N/A	ND	ND
1,1,2-Trichloroethane	μg/m³	N/A	ND	ND
Trichloroethene	μg/m³	≤ 2600	1100	0.62 J
Vinyl Chloride	μg/m³	≤ 560	1.3 J	ND
Tetrachloroethene	μg/m³	≤ 5100	180	ND

Notes:

CFM - cubic feet per minute

DAR - Division of Air Resources

J - Estimated result between laboratory method detection limit and reporting limit

N/A - Not Applicable

NR - Not recorded

- (1) Discharge goal as approved by NYSDEC's letter dated 31 October 2013.
- (2) Discharge goal is for total 1,2-Dichloroethene.

GM-38 Area Groundwater Remediation Groundwater Treatment Plant Naval Weapons Industrial Reserve Plant - Bethpage, NY Controlled Stack Emissions April 2019

DAR Parameters	Units	Discharge Goal ⁽¹⁾	April 2019
Sampling Date			4/3/19
Average Flowrate	CFM	N/A	9,397
Total Flow	ft ³	N/A	395,981,738
Total Flow	m ³	N/A	11,212,954
Trichloroethene	lb/hr	≤ 0.09	0.00002
Vinyl Chloride	lb/hr	≤ 0.02	0.00000
1,2 Dichloroethene	lb/hr	≤ 11	0.00244
1,2-Dichloroethane	lb/hr	N/A	0.00000
Toluene	lb/hr	N/A	0.00000
Total Xylene	lb/hr	N/A	0.00000
1,1,2-Trichloroethane	lb/hr	N/A	0.00000
Tetrachloroethene	lb/hr	≤ 0.18	0.00000

Notes:

CFM - cubic feet per minute

DAR - Division of Air Resources

N/A - Not Applicable

(1) Discharge goal as approved by NYSDEC's letter dated 31 October 2013.





6 June 2019

Mr. Jason Pelton New York State Department of Environmental Conservation Division of Solid & Hazardous Materials 625 Broadway Albany, NY 12233-7252

Subject: GROUNDWATER DISCHARGE MONITORING/AIR EMISSION REPORT

GM-38 AREA, NWIRP BETHPAGE, NY; DER SITE # 1-30-003B-OU 2

MAY 2019 REPORTING PERIOD

Dear Mr. Pelton:

KOMAN Government Solutions, LLC (KGS) is submitting this monthly monitoring report of the groundwater discharge and air emission results for the Groundwater Treatment Plant (GWTP) located at the Former Naval Weapons Industrial Reserve Plant (NWIRP), Bethpage, NY, GM-38 Area. This report was prepared in accordance with GWTP operational requirements for DER Site # 1-30-003B-OU 2, and the SPDES Permit Equivalent # 13003B.

GWTP operational data from 1 May to 31 May 2019 are presented in Attachment A. In the May reporting period, no significant downtime was recorded for the GM38.

As indicated in Attachment A, all SPDES permitted constituents were in compliance with regulatory guidelines during this reporting period.

Please contact me at 610-400-0622 with any questions or concerns you may have regarding this report.

Sincerely,

KOMAN Government Solutions, LLC

Stephane Roy Project Manager

Attachment A: Groundwater and Air Sampling Results from May 2019

Cc: S. Edwards, NYSDEC

D. Hesler, NYSDEC

C. Haas, NYSDEC Region 1 W. Parish, NYSDEC Region 1

R. Wither, NYSDEC Division of Water

- J. Pilewski, NYSDEC Region 1 Water Engineer
- S. Karpinski, NYSDOH
- J. Lovejoy, NCDH
- C. Stein, USEPA Region 2
- G. Ennis, Nassau County Department of Public Works
- S. Urban, Nassau County Department of Public Works
- T. Licata, Town of Oyster Bay
- M. Russo, Town of Oyster Bay
- L. Fly, NAVFAC Mid-Atlantic
- B. Murray, NAVFAC Mid-Atlantic RPM
- G. Pearman, NWIRP Bethpage
- GM-38 Copy

ATTACHMENT A GROUNDWATER AND AIR SAMPLING RESULTS MAY 2019

GM-38 Area Groundwater Remediation Groundwater Treatment Plant

Naval Weapons Industrial Reserve Plant - Bethpage, NY Discharge Monitoring Report May 2019

SPDES Parameters			May 2019 ⁽¹⁾				
Process Stream	Daily Treated Effluent Maximum ⁽¹⁾	Units	RW-1	RW-3 ⁽²⁾	Combined Influent (3) (RW-1 + RW-3)	Treated Effluent	
Well Depth	N/A	ft	445	530	N/A	N/A	
Screened Interval	N/A	ft bgs	335-395 410-430	392-412 442-504	N/A	N/A	
Sampling Date	N/A			5,	/1/19		
Effective Flowrate	1100	GPM	659	168	827	877	
Total Flow	N/A	gallons	29,369,700	7,475,300	36,845,000	39,069,200	
рН	5.5 - 8.5	SU	5.34	5.07	5.29	6.39	
Chloroform	5	μg/L	0.310 J	0.300 J	0.31 J	ND (1.0)	
1,1-Dichloroethane	5	μg/L	1.45 J	2.12 J	1.59 J	ND (1.0)	
1,2-Dichloroethane	0.6	μg/L	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	
1,1-Dichloroethene	5	μg/L	0.880 J	1.11 J	0.927 J	ND (1.0)	
cis 1,2-Dichloroethene	5	μg/L	4.89 J	1.21 J	4.14 J	ND (1.0)	
trans 1,2-Dichloroethene	5	μg/L	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	
Tetrachloroethene	5	μg/L	16.0	0.250 J	12.80	ND (1.0)	
1,1,1-Trichloroethane	5	μg/L	0.610 J	0.550 J	0.598 J	ND (1.0)	
Trichloroethene	5	μg/L	63.1	143	79.3	ND (1.0)	
1,1,2-Trichlorotrifluoroethane	5	μg/L	ND (1.0)	0.800 J	0.16 J	ND (1.0)	
Vinyl Chloride	2	μg/L	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	
1,4-Dioxane		μg/L	2.1	4.5	2.59	2.6	
Mercury	0.00025	mg/L	ND (0.00010)	ND (0.00010)	ND (0.00010)	ND (0.00010)	
Total Suspended Solids (TSS)	N/A	mg/L	ND (1.0)	5.8	1.2	ND (1.0)	

Notes:

- J Estimated result between laboratory method detection limit and reporting limit
- D Concentration is a result of a dilution.
- ND Not detected above laboratory method detection limit. Reporting Limit (RL) given in parentheses.
- NR Not Recorded
- N/A Not Applicable
- NS Not Sampled
- (1) Wastewater discharge equivalence permit renewed on 18 August 2017. Discharge limits established for 10 years. Chloroform, 1,4-dioxane and 1,1,2-trichlorotrifluoroethane are now monitored under the new permit.
- (2) Well RW-3 was placed back in operation on 1 June, 2018.
- (3) Influent concentrations presented are the weighted average concentrations of RW-1 and RW-3.

GM-38 Area Groundwater Remediation Groundwater Treatment Plant Naval Weapons Industrial Reserve Plant - Bethpage, NY Air Sampling Results May 2019

DAR Parameters	May 2019			
Process Stream	Units	Discharge Goal ⁽¹⁾	Influent	Effluent
Sampling Date			5,	/1/19
Average Flowrate	CFM	N/A	NR	8,972
Total Flow	ft ³	N/A	NR	399,909,108
Total Flow	m ³	N/A	NR	11,324,165
1,2-Dichloroethane	μg/m³	N/A	1.9 J	ND
cis 1,2-Dichloroethene	μg/m³	1 100 000 (2)	48	79
trans 1,2-Dichloroethene	μg/m³	≤ 100,000 ⁽²⁾	ND	ND
1,2-Dichloroethene (total)	μg/m³	≤ 100,000	48	79
Toluene	μg/m³	N/A	ND	ND
Total Xylene	μg/m³	N/A	ND	ND
1,1,2-Trichloroethane	μg/m³	N/A	ND	ND
Trichloroethene	μg/m³	≤ 2600	1100	1.3 J
Vinyl Chloride	μg/m³	≤ 560	1.1 J	0.95 J
Tetrachloroethene	μg/m³	≤ 5100	170	ND

Notes:

CFM - cubic feet per minute

DAR - Division of Air Resources

J - Estimated result between laboratory method detection limit and reporting limit

N/A - Not Applicable

NR - Not recorded

- (1) Discharge goal as approved by NYSDEC's letter dated 31 October 2013.
- (2) Discharge goal is for total 1,2-Dichloroethene.

GM-38 Area Groundwater Remediation Groundwater Treatment Plant Naval Weapons Industrial Reserve Plant - Bethpage, NY Controlled Stack Emissions May 2019

DAR Parameters	Units	Discharge Goal ⁽¹⁾	May 2019
Sampling Date			5/1/19
Average Flowrate	CFM	N/A	8,972
Total Flow	ft ³	N/A	399,909,108
Total Flow	m ³	N/A	11,324,165
Trichloroethene	lb/hr	≤ 0.09	0.00004
Vinyl Chloride	lb/hr	≤ 0.02	0.00003
1,2 Dichloroethene	lb/hr	≤ 11	0.00265
1,2-Dichloroethane	lb/hr	N/A	0.00000
Toluene	lb/hr	N/A	0.00000
Total Xylene	lb/hr	N/A	0.00000
1,1,2-Trichloroethane	lb/hr	N/A	0.00000
Tetrachloroethene	lb/hr	≤ 0.18	0.00000

Notes:

CFM - cubic feet per minute

DAR - Division of Air Resources

N/A - Not Applicable

(1) Discharge goal as approved by NYSDEC's letter dated 31 October 2013.





8 July 2019

Mr. Jason Pelton New York State Department of Environmental Conservation Division of Solid & Hazardous Materials 625 Broadway Albany, NY 12233-7252

Subject: GROUNDWATER DISCHARGE MONITORING/AIR EMISSION REPORT

GM-38 AREA, NWIRP BETHPAGE, NY; DER SITE # 1-30-003B-OU 2

JUNE 2019 REPORTING PERIOD

Dear Mr. Pelton:

KOMAN Government Solutions, LLC (KGS) is submitting this monthly monitoring report of the groundwater discharge and air emission results for the Groundwater Treatment Plant (GWTP) located at the Former Naval Weapons Industrial Reserve Plant (NWIRP), Bethpage, NY, GM-38 Area. This report was prepared in accordance with GWTP operational requirements for DER Site # 1-30-003B-OU 2, and the SPDES Permit Equivalent # 13003B.

GWTP operational data from 1 June to 30 June 2019 are presented in Attachment A. In the June reporting period, no significant downtime was recorded for the GM38.

As indicated in Attachment A, all SPDES permitted constituents were in compliance with regulatory guidelines during this reporting period.

Please contact me at 610-400-0622 with any questions or concerns you may have regarding this report.

Sincerely,

KOMAN Government Solutions, LLC

Stephane Roy Project Manager

Attachment A: Groundwater and Air Sampling Results from June 2019

Cc: S. Edwards, NYSDEC

D. Hesler, NYSDEC

C. Haas, NYSDEC Region 1 W. Parish, NYSDEC Region 1

R. Wither, NYSDEC Division of Water

- J. Pilewski, NYSDEC Region 1 Water Engineer
- S. Karpinski, NYSDOH
- J. Lovejoy, NCDH
- C. Stein, USEPA Region 2
- G. Ennis, Nassau County Department of Public Works
- S. Urban, Nassau County Department of Public Works
- T. Licata, Town of Oyster Bay
- M. Russo, Town of Oyster Bay
- L. Fly, NAVFAC Mid-Atlantic
- B. Murray, NAVFAC Mid-Atlantic RPM
- G. Pearman, NWIRP Bethpage
- GM-38 Copy

ATTACHMENT A GROUNDWATER AND AIR SAMPLING RESULTS JUNE 2019

GM-38 Area Groundwater Remediation Groundwater Treatment Plant

Naval Weapons Industrial Reserve Plant - Bethpage, NY Discharge Monitoring Report June 2019

SPDES Parameters			June 2019 ⁽¹⁾				
Process Stream	Daily Treated Effluent Maximum ⁽¹⁾	Units	RW-1	RW-3 ⁽²⁾	Combined Influent (3) (RW-1 + RW-3)	Treated Effluent	
Well Depth	N/A	ft	445	530	N/A	N/A	
Screened Interval	N/A	ft bgs	335-395 410-430	392-412 442-504	N/A	N/A	
Sampling Date	N/A			6,	/3/19		
Effective Flowrate	1100	GPM	658	190	849	888	
Total Flow	N/A	gallons	28,440,905	8,229,550	36,670,454	38,359,733	
рН	5.5 - 8.5	SU	5.23	4.99	5.18	5.92	
Chloroform	5	μg/L	0.290 J	0.310 J	0.29 J	ND (1.0)	
1,1-Dichloroethane	5	μg/L	1.40 J	2.09 J	1.55 J	ND (1.0)	
1,2-Dichloroethane	0.6	μg/L	0.220 J	ND (1.0)	0.17 J	ND (1.0)	
1,1-Dichloroethene	5	μg/L	0.830 J	0.980 J	0.864 J	ND (1.0)	
cis 1,2-Dichloroethene	5	μg/L	4.41 J	1.15 J	3.68 J	ND (1.0)	
trans 1,2-Dichloroethene	5	μg/L	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	
Tetrachloroethene	5	μg/L	17.8	0.250 J	13.86	ND (1.0)	
1,1,1-Trichloroethane	5	μg/L	0.550 J	0.510 J	0.541 J	ND (1.0)	
Trichloroethene	5	μg/L	65.6	142	82.7	ND (1.0)	
1,1,2-Trichlorotrifluoroethane	5	μg/L	ND (1.0)	0.650 J	0.15 J	ND (1.0)	
Vinyl Chloride	2	μg/L	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)	
1,4-Dioxane		μg/L	1.7	4.1	2.2	NS	
Mercury	0.00025	mg/L	ND (0.00010)	ND (0.00010)	ND (0.00010)	ND (0.00010)	
Total Suspended Solids (TSS)	N/A	mg/L	ND (1.0)	6.2	1.4	ND (1.0)	

Notes:

- J Estimated result between laboratory method detection limit and reporting limit
- D Concentration is a result of a dilution.
- ND Not detected above laboratory method detection limit. Reporting Limit (RL) given in parentheses.
- NR Not Recorded
- N/A Not Applicable
- NS Not Sampled
- (1) Wastewater discharge equivalence permit renewed on 18 August 2017. Discharge limits established for 10 years. Chloroform, 1,4-dioxane and 1,1,2-trichlorotrifluoroethane are now monitored under the new permit.
- (2) Well RW-3 was placed back in operation on 1 June, 2018.
- (3) Influent concentrations presented are the weighted average concentrations of RW-1 and RW-3.

GM-38 Area Groundwater Remediation Groundwater Treatment Plant Naval Weapons Industrial Reserve Plant - Bethpage, NY Air Sampling Results June 2019

DAR Parameters	June 2019			
Process Stream	Units	Discharge Goal ⁽¹⁾	Influent	Effluent
Sampling Date			6,	/3/19
Average Flowrate	CFM	N/A	NR	8,631
Total Flow	ft ³	N/A	NR	372,863,970
Total Flow	m ³	N/A	NR	10,558,332
1,2-Dichloroethane	μg/m³	N/A	2.5 J	ND
cis 1,2-Dichloroethene	μg/m³	≤ 100,000 ⁽²⁾	52	79
trans 1,2-Dichloroethene	μg/m³	≤ 100,000 ` ′	ND	2.1 J
1,2-Dichloroethene (total)	μg/m³	≤ 100,000	52	81
Toluene	μg/m³	N/A	1.1 J	ND
Total Xylene	μg/m³	N/A	ND	ND
1,1,2-Trichloroethane	μg/m³	N/A	2.8 J	ND
Trichloroethene	μg/m³	≤ 2600	1100	8.3
Vinyl Chloride	μg/m³	≤ 560	1.1 J	0.89 J
Tetrachloroethene	μg/m³	≤ 5100	180	ND

Notes:

CFM - cubic feet per minute

DAR - Division of Air Resources

J - Estimated result between laboratory method detection limit and reporting limit

N/A - Not Applicable

NR - Not recorded

- (1) Discharge goal as approved by NYSDEC's letter dated 31 October 2013.
- (2) Discharge goal is for total 1,2-Dichloroethene.

GM-38 Area Groundwater Remediation Groundwater Treatment Plant Naval Weapons Industrial Reserve Plant - Bethpage, NY Controlled Stack Emissions June 2019

DAR Parameters	Units	Discharge Goal ⁽¹⁾	June 2019
Sampling Date			6/3/19
Average Flowrate	CFM	N/A	8,631
Total Flow	ft ³	N/A	372,863,970
Total Flow	m ³	N/A	10,558,332
Trichloroethene	lb/hr	≤ 0.09	0.00027
Vinyl Chloride	lb/hr	≤ 0.02	0.00003
1,2 Dichloroethene	lb/hr	≤ 11	0.00262
1,2-Dichloroethane	lb/hr	N/A	0.00000
Toluene	lb/hr	N/A	0.00000
Total Xylene	lb/hr	N/A	0.00000
1,1,2-Trichloroethane	lb/hr	N/A	0.00000
Tetrachloroethene	lb/hr	≤ 0.18	0.00000

Notes:

CFM - cubic feet per minute

DAR - Division of Air Resources

N/A - Not Applicable

(1) Discharge goal as approved by NYSDEC's letter dated 31 October 2013.

APPENDIX B NYSDEC AIR DISCHARGE LIMIT DOCUMENTATION

JUN



Bureau of Water Permits, 4th Floor 625 Broadway, Albany, New York 12233-3505 Phone: (518) 402-8111 • FAX: (518) 402-9029

Website: www.dec.state.ny.us



MEMORANDUM

TO:

Steven Scharf, DER

FROM:

Jean Occidental, DOW, Bureau of Water Permits

SUBJECT:

Naval Weapons Industrial Reserve Plant (NWIRP); DER Site # 1-01-001

DRAINAGE BASIN: na

DATE:

June 6, 2008

In response to your request and the permittee's SPDES Permit Equivalent Application dated April 27, 2008, attached is the effluent criteria for the above noted groundwater remediation discharge.

The Division of Water does not have any regulatory authority over a discharge from a State, PRP, or Federal Superfund Site. The Division of Environmental Remediation will be responsible for ensuring compliance with the attached effluent criteria and approval of all engineering submissions. Additional Condition (1) identifies the contact to send all effluent results, engineering submissions, and modification requests. The Regional Water Engineer should be kept appraised of the status of these discharges and, in accordance with the attached criteria, receive a copy of the effluent results for informational purposes.

If you have any questions, please call me at (518) 402-8116.

Attachment

cc: (w/att)

RWE, Region 1

C. Webber

BWP Permit Coordinator

Naval Weapons Industrial Reserve Plant

Jun 09 08 02:52p

DER site # 1-01-001 Page 1 of 2

EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

During the period begin	ing: April 1, 2009
and lasting until:	April 1, 2014
the discharges from the	entment facility to Groundwater shall be limited and monitored by the operator

the discharges from the treatment facility to Groundwater shall be limited and monitored by the operator as specified below:

Outfall and Parameters	Limite	Limitations		I .	nimum Monitoring Requirements	
	Daily Avg.	Daily Max.	Units	Measurement Frequency	Sample Type	
Treated Groundwater Remediation Discharge from: Recovery Wells 1, 2, and 3						
Flow	Monitor	1100	GPM	Continuous	Recorder	
pH (range)	5.5 -	8.5	SU	Weekly	Grab	
1,1-Dichloroethane	NA	5	µg/l	Monthly 1	Grab	
1,2-Dichloroethane	NA	0.6	µg/l	Monthly 1	Grab	
1,1-Dichloroethene	NA	5	µg/l	Monthly 1	Grab	
cis-1,2-Dichloroethene	NA	5	µg/l	Monthly 1	Grab	
trans-1,2-Dichloroethene	NA	5	µg/l	Monthly 1	Grab	
Tetrachloroethene	NA	5	µg/l	Monthly 1	Grab	
1,1,1-Trichloroethane	NA	5	µg/l	Monthly ¹	Grab	
Trichloroethene	NA	5	µg/l	Monthly ¹	Grab	
Vinyl chloride	NA	2	µg/l	Monthly 1	Grab	
Mercury	NA	0.25	hâ∖l	Monthly ¹	Grab	

Footnotes:

(1) The minimum measurement frequency shall be monthly following a period of 24 consecutive weekly sampling events showing no exceedances of the stated discharge limitations.

Naval Weapons Industrial Reserve Plant

Bura

DER site # 1-01-001 Page 1 of 2

Additional Conditions:

(1) Discharge is not authorized until such time as an engineering submission showing the method of treatment is approved by the Department. The discharge rate may not exceed the effective or design treatment system capacity. All monitoring data, engineering submissions and modification requests must be submitted to:

Steven Scharf
Division of Environmental Remediation
NYSDEC, 625 Broadway
Albany, NY 12233-7015
Phone: (518) 402-9620

With a copy sent to:

Regional Water Engineer NYSDEC - Region 1 Building 40, SUNY Campus Stony Brook, New York 11790-2356 Phone: (631) 444-0354

- (2) Only site generated wastewater is authorized for treatment and discharge.
- Authorization to discharge is valid only for the period noted above but may be renewed if appropriate. A request for renewal must be received 6 months prior to the expiration date to allow for a review of monitoring data and reassessment of monitoring requirements.
- (4) Any use of corrosion/scale inhibitors, biocidal-type compounds, or other water treatment chemicals used in the treatment process must be approved by the department prior to use.
- (5) This discharge and administration of this discharge must comply with the substantive requirements of 6NYCRR Part 750.

NEW YORK STATE DEPARTMENT OF ENVIRONMENTAL CONSERVATION

Division of Environmental Remediation, Remedial Bureau D 625 Broadway, 12th Floor, Albany, NY 12233-7013 P: (518) 402-9676 I F: (518) 402-9773 www.dec.ny.gov

August 31, 2017

Ms. Lora Fly Remedial Project Manager Naval Facilities Engineering Command 9324 Virginia Ave. Bldg. Z-144, Code OPTE3-6 Norfolk, VA 23511

> Re: SPDES Permit Equivalent Application, Naval Weapons Industrial Reserve Plant Site (NWIRP), Bethpage. NYSDEC Site No 130003B

Lora:

The Department of the Navy (Navy) has requested to renew the State Pollutant Discharge Elimination System (SPDES) effluent for the GM-38 groundwater extraction and treatment system. The New York State Department Environmental Conservation (NYSDEC) has reviewed this request and has established discharge limits for the GM-38 system. These discharge limits, and associated reporting requirements, are detailed in the attached memorandum from the NYSDEC Division of Water.

Thanks and please do not hesitate to contact me at (518) 402-9478 or <u>jason.pelton@dec.ny.gov</u> with any questions.

Sincerely,

Jason M. Pelton
Project Manager
Remedial Section B, Remedial Bureau D
Division of Environmental Remediation

ec: B. Caldwell, EnSafe/Resolution Consultants

S. Edwards, NYSDEC

D. Hesler, NYSDEC

C. Haas, NYSDEC Region 1

W. Parish, NYSDEC Region 1

S. Karpinski, NYSDOH

J. DeFranco/J. Lovejoy, NCDOH

L. Thantu, USEPA Region 2



NEW YORK STATE DEPARTMENT OF ENVIRONMENTAL CONSERVATION

Division of Water, Bureau of Permits 625 Broadway, Albany, New York 12233-3505 P: (518) 402-8111 | F: (518) 402-9029 www.dec.ny.gov

MEMORANDUM

TO: Jason Pelton, DER

FROM: Robert Wither, Chief, South Permits Section, DOW

SUBJECT: Naval Weapons Industrial Reserve Plant, DER Site #1-30-003B

DATE: August 18, 2017

In response to your request received July 13, 2017, attached please find effluent limitations and monitoring requirements for the above noted remediation discharge.

The DOW does not have any regulatory authority over a discharge from a State, PRP, or Federal Superfund Site. DER will be responsible for ensuring compliance with the attached effluent limitations and monitoring requirements, and approval of all engineering submissions. Footnote 1 identifies the appropriate DER contact as the place to send all effluent results, engineering submissions, and modification requests. The Regional Water Engineer should be kept appraised of the status of this discharge and, in accordance with the attached criteria, receive a copy of the effluent results for informational purposes.

If you have any questions, please call me at 518-402-8123.

Attachment (Effluent Limitations and Monitoring Requirements)

cc: Cathy Haas, RWE, Region 1



EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

During the period beginning **September 1, 2017** and lasting until **August 31, 2027** the discharges from the wastewater treatment facility to groundwater, Class GA shall be limited and monitored by the operator as specified below:

Outfall Number and Parameter	Discharge L	imitations	11.7.	Minimum Monitoring Requirements	
	Monthly Avg.	Daily Max	Units	Measurement Frequency	Sample Type
Outfall 001 - Treated Remedia	tion Discharge	e :			
Flow	Monitor	1100	GPM	Continuous	Recorder
pH (range)	5.5 -	8.5	SU	Monthly	Grab
1,1-Dichloroethanrie	NA	5	μg/l	Monthly	Grab
1,2-Dichloroethane	NA	0.6	μg/l	Monthly	Grab
1,1-Dichloroethene	NA	5	μg/l	Monthly	Grab
cis-1,2-Dichloroethene	NA	5	μg/l	Monthly	Grab
trans-1,2-Dichloroethene	NA	5	μg/l	Monthly	Grab
Tetrachloroethene	NA	5	μg/l	Monthly	Grab
1,1,1-Trichloroethane	NA	5	μg/1	Monthly	Grab
Trichloroethene	NA	5	μg/l	Monthly	Grab
Vinyl Chloride	NA	2	μg/l	Monthly	Grab
Mercury	NA	0.25	μg/l	Monthly	Grab
Chloroform	NA	5	μg/l	Monthly	Grab
Trichlorotrifluoroethane (Freon 113)	NA	5	μg/l	Monthly	Grab
1,4 Dioxane	NA	Monitor	μg/l	Monthly	Grab

Additional Conditions:

1. The discharge rate may not exceed the effective or design treatment system capacity. All monitoring data, engineering submissions and modification requests must be submitted to:

Jason Pelton
Division of Environmental Remediation
NYSDEC
625 Broadway
Albany, New York 12233- 7015
518-402-9870

With a copy sent to:

Regional Water Engineer, Region 1 NYSDEC SUNY @ Stony Brook 50 Circle Road Stony Brook, NY 11790-3409

- 2. Only site generated wastewater is authorized for treatment and discharge.
- 3. Authorization to discharge is valid only for the period noted above but may be renewed if appropriate. A request for renewal must be received 6 months prior to the expiration date to allow for a review of monitoring data and reassessment of monitoring requirements.
- 4. Both concentration (mg/l or μg/l) and mass loadings (lbs/day) must be reported to the Department for all parameters except flow and pH.
- Any use of corrosion/scale inhibitors, biocidal-type compounds, or other water treatment chemicals used in the treatment process must be approved by the department prior to use.
- 6. This discharge and administration of this discharge must comply with the substantive requirements of 6NYCRR Part 750.

New York State Department of Environmental Conservation

Division of Environmental Remediation Remedial Action Bureau A, 12th Floor

625 Broadway, Albany, New York 12233-7015 Phone: (518) 402-9620 FAX: (518) 402-9022



Joseph Martens Commissioner

October 31, 2013

Lora Fly Remedial Program Manager NAVFAC Mid-Atlantic Northeast IPT 9742 Maryland Avenue Norfolk, VA, 23511-3095

RE: Northrop Grumman, Naval Weapons Industrial Reserve Plant (NWIRP) and Grumman Steel Los Sites, NYSDEC Site No.'s 1-30-003 A & B.

Dear Ms. Fly:

Tetra Tech NUS Inc., on behalf of the Department of the Navy NAVFAC Midlantic, has submitted an application to remove the GM 38 Area Groundwater Extraction and Treatment system impregnated Xeolitetm resin from the air discharge treatment system. Currently, the air treatment system uses a combined activated carbon with permanganate impregnated resin treatment train. The New York State Department of Environmental Conservation (NYSDEC) has reviewed the Department of the Navy application and concurs with the findings presented.

The routine monitoring, as detailed in Table 1, clearly indicates that vinyl chloride, one of the main contaminants of concern, has diminished to almost non-detect, and discharge concentrations have dropped to below the limit to require air treatment for the other contaminants as well. However, NAVFAC Midlantic is still proposing activated carbon to reduce the other discharge contaminant levels. Therefore, the NYSDEC hereby approves the proposed changes to the GM 38 Area air treatment. The Xeolitetm resin beds will remain in place should reactivation, based on routine monitoring, be required.

If you have any questions in the interim, please contact me at (518)402-9620.

Sincerely,

Steven M. Scharf, P.E.

Project Engineer

Remedial Action Bureau A

Division of Environmental Remediation

EC: J. Swartwout

S. Scharf

W. Parish, Region 1

S. Karpinski, NYSDOH

E. Hannon, NGC

D. Stern, Arcadis

D. Brayack, TTNUS



NOR-01264

November 21, 2011

Mr. Stephen Scharf New York Department of Environmental Conservation Division of Environmental Remediation Bureau of Remedial Action A 625 Broadway, 11th Floor Albany, New York 12233-7015

Reference: CLEAN Contract No. N62470-08-D-1001

Contract Task Order WE06

Subject: Proposed Modification to Discharge Limits for Off Gas Volatile Organic Compounds (VOCs)

for Air Stripping Tower

GM-38 Offsite Groundwater Treatment Plant,

NWIRP Bethpage, New York

Dear Mr. Scharf:

On behalf of the Navy, please find enclosed a copy of the subject document. This document presents an evaluation of current concentrations of off gas VOCs from the GM-38 groundwater treatment plant air-stripping tower (prior to treatment with granular activated carbon). Maximum emission rates were reevaluated due to decreasing maximum concentrations of target VOCs in un-treated air stripper AS-1 off gas. In addition, breakthrough of target contaminants (e.g., cis-1,2-dichloroethene) is beginning to occur in the granular activated carbon bed. Maximum emission rates were re-evaluated to provide a determination if breakthrough of contaminants would trigger the need for a replacement of the granular activated carbon bed.

Existing Discharge Goals were established in the "Final Operation, Maintenance and Monitoring Plan for Groundwater Treatment Plant GM-38 Area Groundwater Remediation" prepared by Tetra Tech EC (April 2010). Existing goals were based on emission estimates for a 95% reduction (see Attachment A), instead of being based on the original DAR-1 analysis of air stripper off gas. Emission estimates were calculated using the air stripper design flow rate of 8,000 cubic feet per minute (cfm), and previous contaminant discharge rates in pounds per hour (lb/hr). Original emission estimates are provided in Attachment B.

Proposed Revised Discharge Goals were calculated using an average flow rate of 9,200 cfm, January to March 2011 VOC loading rates (taken from the Quarterly Operations Report First Quarter 2011 from ECOR Federal Services), and the Actual Annual % of Annual Guideline Concentrations (AGCs), taken from the revised DAR-1 Model Output. The revised DAR-1 Model Output is provided in Attachment C. Existing Discharge Goals and Proposed Revised Discharge Goals are compared in tabular format in the first page of the attachment. Proposed Revised Discharge Goals for trichloroethene (TCE) are the same as previous. The proposed limit for tetrachloroethene (PCE) is approximately 10 times the previous limit, and vinyl chloride is approximately 2 times the previous limit. Revised Discharge Goals for 1,2-dichloroethene (goals are the same for cis-1,2-dichloroethene) are 100 times greater than previously established limits. It is recommended that these revised limits replace previous discharge goals, and treatment of air stripper off gas by granular activated carbon is recommended to continue for TCE and PCE, with no treatment required for vinyl chloride and 1,2-dichloroethene.

NOR-01264

Proposed Modification to Discharge Limits for Off Gas Volatile Organic Compounds (VOCs) NWIRP Bethpage 11-21-11 - Page 2

If you have any questions please contact Ms. Lora Fly, NAVFAC Mid-LANT, at (757) 341-2012.

Sincerely,

David D. Brayack, P.E.

Project Manager

Enclosure:

(1) Proposed Modification to Discharge Limits for Off Gas Volatile Organic Compounds

(VOCs) for Air Stripping Tower

GM-38 Offsite Groundwater Treatment Plant

Distribution:

Mid-Lant, Lora Fly NYSDEC (Albany), Henry Wilkie NYSDOH (Troy), Steve Karpinski NAVAIR, Richard Smith USEPA, Carol Stein NGC, Kent Smith Tetra Tech NUS, Dave Brayack ECOR Solutions, Al Taormina Administrative Record Public Repository Project File

TABLE 1
COMPARISON OF EXISTING DISCHARGE GOALS WITH ACTUAL EMISSIONS AND PROPOSED DISCHARGE GOALS
AIR STRIPPING TOWER GM-38 OFFSITE GROUNDWATER TREATMENT PLANT
NWIRP BETHPAGE, NEW YORK

	Existing Dis	charge Goal	Actual January to N (Pre-Off Gas	March 2011 Values Treatment)	Proposed Revised Discharge Goals based on DAR-1 Analysis		
Chemical	Existing Discharge Loading Rate (pounds (lbs)/hour) ⁽¹⁾ Equivalent Existing Discharge Goals (µg/m³) ⁽²⁾		Actual Jan-Mar 2011 Concentration (μg/m³) ⁽³⁾	Actual VOC Loading Pre-Off Gas Treatment (lbs/hour) ⁽⁴⁾	Proposed Discharge Loading Rate (lbs/hour) ⁽⁵⁾	Equivalent Proposed Discharge Goal (µg/m³) ⁽⁵⁾	
TCE	0.09	2,600	10,000	0.345	0.09	2,600	
PCE	0.02	580	6,800	0.234	0.18	5,100	
Vinyl Chloride	0.01	290	76	0.003	0.02	560	
1,2-Dichloroethene (total)			750	0.026	11	greater than 100,000	

Notes:

⁽¹⁾ Existing Discharge Goals are based on the design flow rate of 8,000 cfm. Existing Discharge Goals were taken from the Final Operations and Maintenance Plan for GM-38 Area Groundwater Remediation from Tetra Tech EC. Existing goals were based on emission estimates for a 95% reduction, and not the previous DAR-1 Analysis. Attachment B (provided at the end of this package) provides the original emission estimates.

⁽²⁾ Existing Discharge Goals were calculated using the actual flow rate of 9,200 cfm and the existing discharge loading rate in pounds per hour (lb/hr).

⁽³⁾Values were taken from the Quarterly Operations Report First Quarter 2011 from ECOR Federal Services. Values were the maximum effluent concentration in off gas from air stripper stack AS-1 prior to treatment with vapor phase granular activated carbon (GAC), for the months of January, February and March 2011.

⁽⁴⁾Actual VOC Loading was calculated using an average flow rate of 9,200 cfm and the January-March 2011 concentrations. Existing off gas treatment consists of two stage vapor phase GAC followed by potassium permanganate zeolite media to provide additional treatment for vinyl chloride.

⁽⁵⁾ Values were calculated using an average flow rate of 9,200 cfm, and the Actual Annual % of the AGCs from the 2011 DAR-1 Model Output to achieve air quality requirements.

ATTACHMENT A 2008 AIR PERMIT SUBMITTAL

New York State Department of Environmental Conservation Air Permit Application



DEC ID A	APPLICATION ID	7		OFFICE USE ONLY
	l - Certificatio	n		
	V Certification			
l certify under penalty of law that this document and all attachments were prep that qualified personnel properly gather and evaluate the information submitte	ted. Based on my inqui	iry of the person	or persons directly	responsible for gathering the
information [required pursuant to 6 NYCRR 201-6.3(d)] I believe the informat submitting false information, including the possibility of fines and imprisonmen			am aware that there) are significant penalties for
Responsible Official		Title	е	
Signature		Dat	te <u>/</u>	1
	cility Certification			
I certify that this facility will be operated in conformance with all prov	visions of existing reg			
Responsible Official		Title		
Signature		Date	ie <u>/</u>	
Section II - Iden	ntification Info	rmation		
Title ∨ Facility Permit N/A □ New □ Significant Modification □ Administrative A	mandmant	Stat	te Facility Permit	N/A □ Modification
☐ New ☐ Significant Modification ☐ Administrative A: ☐ Renewal ☐ Minor Modification ☐ General Permit Title			vew neral Permit Title:	U Modification
☐ Application involves construction of new facility	☐ Application	involves const	truction of new em	nission unit(s)
	- 1 - 1 - 1 - 1 - 1 - 1 - 1 - 1 - 1 - 1			
	wner/Firm			
Name US Navy/NAVFAC Midlant				
Street Address 9742 Maryland Ave, Bldg Z-144	1			- 22511 2005
City Norfolk Owner Classification ⋈ Federal	State VA	Cou Municipal	•	Zip 23511-3095 Taxpayer ID
□ Corporation/Partnership	☐ Individual	— 10.00		
	Facility			🗅 Confidential
Name Naval Weapons Industrial Reserve Plant (N	WIRP) GM-38	Area		
Location Address Bethpage				
□ City / XI Town / □ Village Oyster Bay, New York				^{Zip} 11714
Project	ct Description			☐ Continuation Sheet(s)
Air stripping of groundwater to remove VOCs				
Owner/Firm Co	ontact Mailing Ad	ddress		
Name (Last, First, Middle Initial) Fly, Lora			_	757)444-0781
Affiliation Department of the Navy	Title Remedial	PM	Fax No.()	
Street Address 9742 Maryland Ave. Bldg Z-144				
City Norfolk	State VA		JS	Zip 23511-3095
	tact Mailing Add	ress		
Name (Last, First, Middle Initial) Same	Ţ		Phone No. (
Affiliation	Title		Fax No.()	
Street Address				
ICity I	State	Country		Zip

12/21/01 PAGE 1

New York State Department of Environmental Conservation



Air Pe	ermit Ap	plicatio	n									
T. I	DEC IE	<u> </u>	\Box									
	L		L F									
			<u> </u>	ection II	I - Facility I) 					
Hosp	Classification ☐ Hospital ☐ Residential ☐ Educational/Institutional ☐ Commercial ☒ Industrial ☐ Utility											
- 1100p	itai _	Neside III.		loadona	Sulduona	<u> </u>	TCIAI	uuşiria.	-			
				Affecte	d States (Titl	e V Only)	 N/A					
☐ Verm		☐ Massad		☐ Rhod ☐ New J		⊒ Pennsylvania ⊒ Ohio						
T New	Hampshire	G Connec		I NEW 0								
					SIC Codes							
9999	Т		Т	-T	Sic codes		-T T	Τ.				
9990	+ +											
					acility Descrip				nuation Sheet(s)			
Gr	roundwater	Remedia	tion by Air S	tripping fo	ollowed by Va	por-Phase (GAC for emiss	sion contro)l			
 												
				ompliance	Statements	(Title V Only) N/A					
i certif	ly that as of th	e date of this				<u> </u>	uirements: 🖸 YES	S D NO				
••			•	•	, ,		s at the time of sig on page 8 of this fo					
plan in	nformation req						e with all applicable					
follow	This facilit	•	•				compliance for the	duration of the	ne permit, except			
					on of Section IV on uirements that w		n. ive during the term	n of the perm	it, this facility will			
	meet all s	uch requireme	ents on a timely	basis.			rill certify complian					
	-		ethod used to d						1100000110 0001			
				 _	cable Federa			_	nuation Sheet(s)			
Title	Туре	Part		Section	Sub Division	Paragraph	Sub Paragraph	Clause	Sub Clause			
 	CERCLA	A Jali Si	ubstantive	requirer	nents							
				_	, , , , , , , , , , , , , , , , , , , ,							

			Fac	Facility Applicable Federal Requirements N/A ☐ Continuation Sheet(s)										
Title	Туре	Part	Sub Part	Section	Sub Division	Paragraph	Sub Paragraph	Ctause	Sub Clause					
	CERCLA	all su	bstantive	requirer	nents									
			_											
									_					

		☐ Contir	nuation Sheet(s)						
Title	Туре	Part	Sub Part	Section	Sub Division	Paragraph	Sub Paragraph	Clause	Sub Clause
	_								
	, , , , , , , , , , , , , , , , , , , ,								_

12/21/01 PAGE 2

New York State Department of Environmental Conservation Air Permit Application



DEC ID										
Π-	Т				1					

Section III - Facility Information (continued)

			Fac	ility Complia	nce Certific	ation N/A	<u> </u>	ontinuati	on Sheet(s)
_				Rule (Citation				
Title	Туре	Part	Sub Part	Section	Sub Division	Paragraph	Sub Paragraph	Clause	Sub Clause
Applicable	Federal Requirement	C	CA	AS No.		Cor	ntaminant Name		
State Only	Requirement	Capping							
				Monitoring	Information				
☐ Ambient	Air Monitoring	☐ Work P	ractice Inv	olving Specifi	Operations	□ Reco	rd Keeping/Maint	enance F	Procedures
				Desc	ription				
			_						
Work Prac	ctice		Process	Material			Reference T	est Meth	nd .
Туре	Code			Description			. Reference i	est Metho	
		Para	<u>meter</u>				Manufacturer Na	ame/Mod	el No
	Code			Description	_				
	Limit			Code		Limi	t Units		
	Upper Lower				Description				
	Averaging Method			Monitoring I	requency		Reporting Re	quiremer	nts
Code	Descript	ion	Code		Description Code Descri			Descripti	ion

	Facility Emissions Summary		☐ Continu	ation Sheet(s)
CAS No.	Contaminant Name	PTE (lbs/yr)	Range	Actual (lbs/yr)
NY075 - 00 - 5	PM-10	(1000)	Code	
NY075 - 00 - 0	PARTICULATES			
7446 - 09 - 5	SULFUR DIOXIDE			
NY210 - 00 - 0	OXIDES OF NITROGEN			
630 - 08 - 0	CARBON MONOXIDE			
7439 - 92 - 1	LEAD			
NY998 - 00 - 0	VOC	117		
NY100 - 00 - 0	HAP	110		
0079 - 01 - 6	Trichloroethylene	99		
00075 - 01 - 4	Vinyl Chloride	3.7		
00540 - 59 - 0	1,2-Dichloroethylene	7.3		

7

PAGE 3

12/21/01

New York State Department of Environmental Conservation Air Permit Application



	DEC ID										
П	-					<u> </u>					

Section IV - Emission Unit Information

Emission Unit Description	☐ Continuation Sheet(s)
EMISSION UNIT 0 - 0 0 E U 1	
Air Stripper AS-1 for groundwater remediation, provided with activated carbon for	emission control.
The emission point is stack 00ST-1. The 2-stage VGAC is followed by a 3r	rd vessel containing
a potassium permanganate zeolite media for increased VC capacity.	

	Building	☐ Continuation Sheet(s)		
Building	Building Name	Length (ft)	Width (ft)	Orientation
BLDG-1	Treatment Plant	75	75	0

			Emission Poir	nt	☐ Cont	inuation Sheet(s)
EMISSION PT.	oos⊤1					
Ground Elev.	Height	Height Above	Inside Diameter	Exit Temp.	Cross S	Section
(ft)	(ft)	Structure (ft)	(in)	(°F)	Length (in)	Width (in)
90	40	15	36	80		
Exit Velocity _(FPS)	Exit Flow (ACFM)	NYTM (E) (KM)	NYTM (N) (KM)	Building	Distance to Property Line (ft)	Date of Removal
19	8020			BLDG-1	50	
EMISSION PT.						
Ground Elev.	Height	Height Above	Inside Diameter	Exit Temp.	Cross S	Section
(ft)	(ft)	Structure (ft)	(in)	(°F)	Length (in)	Width (in)
Exit Velocity (FPS)	Exit Flow (ACFM)	NYTM (E) (KM)	NYTM (N) (KM)	Building	Distance to Property Line (ft)	Date of Removal

Emission Source/Control Continuation Sheet(s)								
Emission	Source	Date of	Date of	Date of	Control Type		Manufacturer's Name/Model	
ID	Туре	Construction	Operation	Removal	Code	Description	No.	
AS-1	1				048	Granular Act. Carbon	Air Stripping Column	
Design Capacity	Design Capacity Units				Waste Feed		Waste Type	
	Code	Description			Code	Description	Code	Description
				_				
Emission	Source	Date of	Date of	Date of	Control Type		Manufacturer's Name/Model	
ID	Type	Construction	Operation	Removal	Code	Description	No	
Design Capacity	Design Capacity Units				Waste Feed		Waste Type	
	Code	Code Description			Code	Description	Code	Description

12/21/01 PAGE 4



)E()		
ГТ	- 1			-			

Section IV - Emission Unit Information (continued)

							Pro	cess Ir	nformation			□ Contin	uation	She	eet(s)
EMISSION UN	ΙΤ	0 -	00	E	U	1						PROCE	SS	РΙ	R 1
								Descr	ription						
The rem	nec	lial s	vstem	is a	air s	strippir	ng. usi	ng a pa	acked column	n at a ground	water	flow rat	te of		
1,100 g	pm	ı (plu	ıs 100	gpr	m r	ecycle	, for a	total o	f 1,200 gpm)	Vapor phas	e trea	tment in	nclud	es	
the use	of	3 ve	ssels,	a 2	-sta	age G/	AC uni	t, follov	ved by a 3rd	vessel contai	ning a	potass	ium		
perman	ga	nate	impre	gna	ted	zeolit	e for ir	ncrease	ed VC capaci	ity. Prior to e	nterin	g the va	por-p	ha	se
GAC ad	sor	ption	syster	n, th	e h	umidity	of the	air strip	oper exhaust i	s reduced to a	pproxi	mately			
							_		vapor-phase (
Air	Str	ipper	· AS-1:	Exis	stin	g. Typ	e: Ver	tical, Cy	ylindrical Con	struction: Alun	ninum				
Pac	kin	g: 2 5	-foot J	aege	er T	ripack	Dime	nsions:	10.0 ft. Dia x	47 ft. H					
Source Cla			n			Total T	hruput			Thruput Qu	uantity (Jnits			
Code	(SC	(C)		Qι	uant	ity/Hr	Quan	tity/Yr	Code		Des	cription			
										<u> </u>				_	
	☐ Confidential ☐ Coperating Schedule ☐ Operating Schedule ☐ Hrs/Day ☐ Days/Yr ☐ Activity with Insignificant Emissions ☐ Emission Source/Control Identifier(s) ☐ AS-1 ☐ Derating Schedule ☐ Hrs/Day ☐ Days/Yr ☐ Building ☐ Floor/Location ☐ Main ☐ Emission Source/Control Identifier(s)														
	☐ Activity with Insignificant Emissions 24 365 BLDG-1 Main Emission Source/Control Identifier(s)														
	Emission Source/Control Identifier(s)														
AS-1															
EMISSION UN	ΙΤ	Π-			`							PROCE	ESS		
								Descr	ription						
									<u> </u>						
												_			
Source Cla			n			Total T	hruput			Thruput Qu	uantity (Jnits			
Code	(SC	(C)		Qı	uant	ity/Hr	Quan	tity/Yr	Code		Des	cription			
														_	
☐ Confider ☐ Operatin			imum C	2020	itv				Schedule	Building		Floor/L	ocatio	n	
☐ Operation	_			•	-	ıs	FILS	/Day	Days/Yr						
						E	mission	Source/0	Control Identifier	r(s)	•				
_						_	\$		_						



			EC) IC	<u> </u>		
-	T	П		-			

Section IV - Emission Unit Information (continued)

Emission	Emission Point		Emission		Emi	ssior	Unit App	licable Fe	ederal Requ	irement	s 🗆 Co	ntinuat	ion Sheet(s)
Unit	Point	Process	Source	Title	Туре	Part	Sub Part	Section	Sub Division	Parag.	Sub Parag.	Clause	Sub Clause
-													
-													
-													
-													

Emission	Emission	D	Emission			ssior	Unit State	e Only R	equirements		□ Cc	ntinuat	ion Sheet(s)
Unit	Point	Process	Source	Title	Туре	Part	Sub Part	Section	Sub Division	Parag.	Sub Parag.	Clause	Sub Clause
-													
-													
-													
-													

				Emissio	n Unit Co	mplian	ce C	ertification	_	ūc	ontinuati	on Sheet(s)		
					Rule	Citatio	n							
Title		Туре	Part	Sub Part	Section	Sub Div	ision	Paragraph	Sub F	Paragraph	Clause	Sub Clause		
6	NY	′CRR	212											
X App	olicable	e Federal R	equiremen	: <u> </u>	State Only I	Requirem	ent	☐ Capping						
Emission	Unit	Emission Point	Process	Emission Source	CA	AS No.			Co	ntaminant N	ame ·			
0-00El	J1	00ST1	PR1	AS-1	00079 -	01	- 6	Trichlo	roethy	/lene				
					Monitorir	ng Infor	matic	on						
⊠ inte	ermitte	us Emissior nt Emissior ir Monitorin)	□ Work	Practice I	nvolvir	s or Control De ng Specific Op ntenance Proc	eration	s	as Surro	gate		
					Des	scriptio	า							
Monthly	Monthly grab samples analyzed for VOCs from the vapor phase treatment system influent, effluent and two intermediate locations.													
	ionthly grab samples analyzed for vocs from the vapor phase treatment system initiality, emident, and two intermediate location													
		_												
Work Pra	ctice			Process	Material				Re	ference Te	est Metho	d		
Туре		Code			Description				110	—	- St WIGHT	u		
			Pa	rameter _					Manuf	acturer Na	me/Mode	al No		
	Code				Description				Mulla			,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,		
23			Con	centration	<u> </u>									
		Lim	it					Limit	Units					
	Upper		L	.ower	Code				Description					
	3,125				255	n	nicrog	rams per cu	ms per cubic meter					
	Avera	ging Metho	d		Monitoring	Frequen	су	Reporting Requirements			ts			
Code		Descri	otion	Code		Descript	on	Cod			Descripti			
01	ln:	stantaneo	us	05	Mo	nthly		10		Upon	Reques	it		

12/21/01 PAGE 6



		EC) [)		
_			-			

Section IV - Emission Unit Information (continued)

				etern	ninati	on of Non-A	pplica	bility	(Title	V Only	<u>')</u>	N/A	□ Con	tinuat	ion Sh	eet(s)
						Rule	Citatio	n		_		-				
Title	Туре		Part	Sub	Part	Section	Sub Divi	sion	Par	agraph	Sub	Paragrap	oh Cla	ause	Sub (Clause
Emission	n Unit	Emiss	ion Point	Proc	ess	Emission	Source			oplicable F			ment			
									U 50	ate Only R	equire	ment				
			,			Desc	ription	_								
													_			
							-									
	_					Rule	Citatio	า								_
Title	Туре		Part	Sub	Part		Sub Divi		Par	agraph	Sub	Paragrap	oh Cla	ause	Sub (Clause
Emission	n Unit	Emiss	sion Point	Proc	ess	Emission	Source			oplicable F			ment			
									□ St	ate Only R	Require	ment		_		
						Desc	ription									
	_															
				_			_									
		_		_									_			
										_	_					
	Process						sions S	Sumn	nary				□ Cont	tinuat	ion Sh	eet(s)
EMISSI	ON UNIT	0	- 0 0	ΕU	1								PROC	ESS	P	R 1
CA	S No.			Contan	ninant N	Name			6	%		%	ERP		ERP	
		_						Inn	uput	Capture		ontrol	(lbs/hr		Deten	ninea
0079	<u>- 01 - 6</u>		<u>Trichloroe</u>	thyler	n <u>e</u>		т					95	1.8		02	
			PTE		-		-	andar	ď		E Ho			Act		
(lb:	s/hr)		(lbs/yr)		(sta	ndard units)		Units			ermin	ea	(lbs/hi	r)	(lbs	/yr)
0.	.09	Ц.,	99							02	2				-	
EMISSI	ON UNIT	0	- 00	E U	1								PROC	ESS	P	R 1
CA	S No.			Contarr	ninant N	Name			6	%		% ontrol	ERP (lba/br	٠	ERP Deterr	
00075	. 01 4	1 1/2	I Chilani	: .1 .		_		Inn	uput	Capture	+		(lbs/hr			riirieu
00075	- 01 - 4	VI	nyl Chlor	iae			Т	<u> </u>				95	0.17		03	
			PTE		, .		-	andar Units	ď	1	E Hov ermin		/11. "	Act		()
<u>`</u>	s/hr)	_	(lbs/yr) (standard units)			ndard units)	-	-				-	(lbs/hi	r)	(lbs	/yr)
0.0			3.7	- 1	- 1						02				To T	5 L 4
EMISSI	ON UNIT	0 - 0 0 E U 1								_		PROC	ESS	Р		
CAS	S No.		Contaminant Name					6 uput	% Capture		% ontrol	ERP (lbs/hr	,	ERP Deterr		
000540	- 50 - 0	1.	1.2-Dichloroothylana				1111	apar	Supture	+			<i>'</i>			
000540	<u>- 59 - 0</u>	∠را	1,2-Dichloroethylene			1 .	L				95	0.6	L Act	<u>0</u>		
	- /l- =\		PTE (the standard smith)		ndordit-\	-	andar Units	d		E Hov		/lh = /h :	_		(ver)	
	s/hr)	+	(lbs/yr)		(sta	ndard units)	<u> </u>					-	(lbs/hı)	(lbs	/ y r)
0	.03		7.3								02					



			Е	EC) IE			
\Box	-							

Section IV - Emission Unit Information (continued)

EMISSION UNIT 0 - 0 0 E U 1	Emiss	ion Unit Emissions	Summary	☐ Continuation Sheet(s)
CAS No.		Contami	nant Name	
00107- 06 - 2	1,2-Dichloroethane			
500 (II /)	PTE Em	nissions	Acti	ual
ERP (lbs/yr)	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)
13.4	Below Reporting Th	reshold BRT		
CAS No.		Contami	nant Name	
00108 - 88 - 3	Toluene			
ERP (îbs/ÿr)	PTE Em	nissions	Acti	ual
ERP (IDS/yr)	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)
72.7	BRT	BRT _		
CAS No.		Contami	nant Name	
01330-20 -7	Xylene			
ERP (lbs/yr)	PTE Em	nissions	Actu	ual
ERP (IDS/yl)	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)
77.1	BRT	BRT		
CAS No.		Contami	nant Name	
	1,1,2-Trichloroethan	e		
ERP (lbs/yr)	PTE Em	nissions	Actu	ıal
EINF (IDS/yl)	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)
	BRT	BRT .		

					Сс	mpliano	ce Plar	1		Co	ntinuati	on Sheet(s)		
For any emis	sion units	s which ar	e <u>not in c</u>	ompliand	<u>ce</u> at th	e time of p	ermit ap	plication, the	applica	nt shall comp	lete the	following		
Consent Ord	er		Certifie	d progre	ss rep	orts are to	be subm	nitted every 6	months	beginning_	1			
Emission		Emission					Applicabl	e Federal Requ	irement					
Unit	Process	Source	Title	Туре	Part	Sub Part	Section	Sub Division	Parag.	Sub Parag.	Clause	Sub Clause		
-	- Date													
	Remedial Measure / Intermediate Milestones R/I Date Scheduled													
		_												
			·		_									
		_				_								
						_								
		_				_								
								_						
			<u> </u>											



		EC) IE)		
-			-			

Section IV - Emission Unit Information (continued)

		Requ	uest for Emiss	sion Red	duc	tion	Cre	dits	<u> </u>			2 Cor	ntinua	tion S	Sheet(s)
EMISSION UNIT	_														
			Emission Rec	luction E	Des	crip	tion				_				
								_							
_					_			_				_			
					_		_	_							
<u></u>		Con	taminant Emi	ssion R	edı	uctio	on Da	ata				J 4.		_	
Baseline Period	. ,	,	to /	,				\vdash		Date	Ked	ductio		ethod	1
Daseille Period			10			- .		┢		1		T			_
CAS No.			Contaminant	Nama	_	_		t			ERC	(lbs/			
CAS No.	_		Contaminant	Naiile	_			₽		Vetting		F	(Offset	
					_			╀				╄			•
	-	_			_			╀		_		╄			
	-			F	<u> </u>	-l	4:	_			_	<u> </u>	-		
Name			acility to Use	ruture	ΙKE	auc	uon	_		APPLIC	ATION	חו			
Ivanie						<u>-</u>		Τ	<u> </u>	AFFEIG	TI	ĽΤ	1		T-1.
Location Address															
☐ City / ☐ Town / ☐ V	/illage				St	ate					Zip				
		U:	se of Emissio	n Reduc	tio	n Ci	redit	s S				l Cor	- ntinua	tion S	heet(s)
EMISSION UNIT	T- T			_											
		<u> </u>	Proposed Pr	oject De	esc	ripti	on	_		_					
			-												
		Cor	ntaminant Em	issions I	nc	reas	e Da	at <u>a</u>			_				
CAS No.	·		Contaminan	t Name							PEI	P (lbs	s/yr)		
	-													_	
			Statement	of Com	plia	nce									
All facilities under th including any compli schedule of a conser	iance certifica	f this "ownership/ tion requirements	firm" are operating s under Section 11	g <u>in compli</u> 14(a)(3) of	ianc the	e wit Clea	h all a n Air A	appli Act A	cable Amend	requiren ments o	nents ar of 1990,	nd stat	te regu e meet	lation ing the	s
		Source	of Emission F	Reductio	n (Crec	lit - F	ac	ility						
Name								_		PEF	rmit id				
I a and a make the same					L_	-			-	<u> </u>			/		
Location Address						_					1_:				
☐ City / ☐ Town / ☐ Village					Sta		_		1		Zip	C (lhe	s/vr)		
Emission Unit	CA	S No.	Cont	aminant l	Nar	ne			ERC (lbs/yr) Netting Offset				et		
-															
-															
+		-													
							_					_	_		

PAGE 9



	_		ν) IC	_		
Π-	Г			-	Г		

Supporting Documentation	
☑ P.E. Certification (form attached)	
☐ List of Exempt Activities (form attached)	
🔯 Plot Plan	
☐ Methods Used to Determine Compliance (form attached)	
🖾 Calculations	
☐ Air Quality Model (/)	
☐ Confidentiality Justification	
☐ Ambient Air Monitoring Plan (/)	
☐ Stack Test Protocols/Reports (/)	
☐ Continuous Emissions Monitoring Plans/QA/QC(//)	
☐ MACT Demonstration(/)	
☐ Operational Flexibility: Description of Alternative Operating Scenarios and Protocols	
☐ Title IV: Application/Registration	
☐ ERC Quantification (form attached)	
☐ Use of ERC(s) (form attached)	
☐ Baseline Period Demonstration	
☐ Analysis of Contemporaneous Emission Increase/Decrease	
☐ LAER Demonstration(/)	
☐ BACT Demonstration(/)	
☐ Other Document(s):(/ /)
)
)
·)
	— <u> </u>
(/ /)
)
)
)
)

PAGE 10

ATTACHMENT B 2008 EMISSION ESTIMATES BASED ON 95% REMOVAL

ATTACHMENT 1 **Emission Estimate**

POTENTIAL EMISSION ESTIMATES, USED TO DEVELOP 95%, REDUCTION OF EMISSION VALUES AS BASED ON INFLUENT GROUNDWATER CONCENTRATIONS (95%, REDUCTION OF EMISSION

· Feed Water Flow 1,100 gpm: max or normal

250 m³/hr

Water Flow Including Recycle 1,200 gpm: max or normal

273 m³/hr

Air Flow 8,000 cfm

13.592 m³/hr

50 A/W vol ratio

EXAMPLE EMISSION CALC: Vinyl Chloride

4.8 $ug/L \times 1000 L/m^3 \times 250 m^3$ water/13,623 m^3 air = 88 ug/m^3 VALUES ARE PROVIDED

ON PAGE 7 OF THE 2008 AIR PERMIT APPLICATION PROCESS EMISSIONS SUMMARY)

					GW Co	nc.1	Effluent	Conc ¹			Unc	ontrolled	Stripper Ex	khaust		
`	CAS	Toxicity:			Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg
Name	Number	H/M/L ²	VOC³	HAP⁴_	ug/L	ug/L	ug/L	ug/L	lb/day	lb/day	lb/hr	lb/hr	gm/sec	gm/sec	ug/m ³	ug/m ³
1,1,1-Trichloroethane (Methyl Chloroform)	00071-55-6	L	No	Yes	3	3.0			0.04	0.04	0.00	0.00	2.08E-04	2.08E-04	55	55
1,1,2-Trichloroethane	00079-00-5	M	Yes	Yes	3.5	0.3			0.05	0.00	0.00	0.00	2.43E-04	2.08E-05	64	6
1,1-Dichloroethane	00075-34-3	L	Yes	Yes	4	0.7			0.05	0.01	0.00	0.00	2.77E-04	4.85E-05	74	13
1,2-Dichloroethane	00107-06-2	M	Yes	Yes	3	1.0	0.3	0.1	0.04	0.01	0.00	0.00	1.87E-04	6.24E-05	55	18
1,1-Dichloroethylene (Vinylidene Chloride)	00075-35-4	M	Yes	Yes	9	1.6			0.12	0.02	0.00	0.00	6.24E-04	1.11E-04	165	29
1,2-Dichloroethylene	00540-59-0	M	Yes	No	1,100	31,5	1.3	0.0	14.51	0.42	0.60	0.02	7.62E-02	~2.18E-03	20,219	579
Benzene	00071-43-2	Н	Yes	Yes	4	0.1			0.05	0.00	0.00	0.00	2.77E-04	6.94E-06	74	2
Carbon Tetrachloride	00056-23-5	Н	Yes	Yes	4	0.1	•		0.05	0.00	0,00	0.00	2.77E-04	6.94E-06	74	2
Chlorobenzene (Monochlorobenzene)	00108-90-7	M	Yes	Yes	1	0.1			0.01	0.00	0.00	0.00	6.94E-05	6.94E-06	18	2
Chloroform	00067-66-3	M	Yes	Yes	2	0.8			0.03	0.01	0.00	0.00	1.39E-04	5.55E-05	37	15
Methyl Tert Butyl Ether	01634-04-4	M	Yes	Yes	2	0.1			0.03	0.00	0.00	0.00	1.39E-04	6.94E-06	37	2
Tetrachloroethylene	00127-18-4	M	Yes	Yes	900	.33.8	0.9	0.0	11.88	0.45	0.49	0.02	6.24E-02	2.34E-03	16,543	621
Toluene	00108-88-3	L	Yes	Yes ·	15	0.7			0.20	0.01	0.01	0.00	1.04E-03	4.85E-05	276	13
Trichloroethylene	00079-01-6	M	Yes	Yes	3,400	411.5	4.5	0.5	44.86	5.43	1.87	0.23	2.35E-01	2.85E-02	62,494	7,564
Vinyl chloride	00075-01-4	Н	Yes	Yes	300	4.8	0.0	0.0	3.96	0.06	0.17	0.00	2.08E-02	3.33E-04	5,514	88
Xylenes	01330-20-7	M	Yes	Yes	16	0.2			0.21	0.00	0.01	0.00	1.11E-03	1.39E-05	294	4
Total VOCs					5,764	487.3	7.0	0.6	76.05	6.43	3.17	0.27				
Total HAPs					4,667	458.8	5.7	0.6	61.57	6.05	2.57	0.25				*

Total Uncontrolled VOC 2,347 lb/yr Total Uncontrolled HAP 2,209 lb/yr

1. Source: "GM-38 Groundwater Remedy Analysis Report", February 2003

2. Source: DAR-1 AGC/SGC Tables, NYSDEC Division of Air Resources, Air Toxics Section, September 10, 2007.

3. Source: 6 NYCRR Part 200 1(cg)

4. Source: 6 NYCRR Part 200.1(ag)

ATTACHMENT 1 Emission Estimate

Total Controlled VOC

Total Controlled HAP

117 lb/yr 110 lb/yr

Feed Water Flow 1,100 gpm: max or normal

250 m³/hr

Water Flow Including Recycle 1,200 gpm: max or normal

273 m³/hr

Air Flow 8,000 cfm

13,592 m³/hr

A/W vol ratio 50

							Controlled Stripper Exhau			
	CAS	Toxicity:			Control by	Max	Avg	Max	Avg	
Name	Number	$H/M/L^2$	VOC3	HAP ⁴	GAC	lb/day	lb/day	gm/sec	gm/sec	
1,1,1-Trichloroethane (Methyl Chloroform)	00071-55-6	L	No	Yes	95%	0.00	0.00	1.04E-05	1.04E-05	
1,1,2-Trichloroethane	00079-00-5	M	Yes	Yes	95%	0.00	0.00	1.21E-05	1.04E-06	
1,1-Dichloroethane	00075-34-3	L	Yes	Yes	95%	0.00	0.00	1.39E-05	2.43E-06	
1,2-Dichloroethane	00107-06-2	M	Yes	Yes	95%	0.00	0.00	9.36E-06	3.12E-06	
1,1-Dichloroethylene (Vinylidene Chloride)	00075-35-4	M	Yes	Yes	95%	0.01	0.00	3.12E-05	5.55E-06	
1,2-Dichloroethylene	00540-59-0	M	Yes	No	95%	0.73	0.02	3.81E-03	1.09E-04	
Benzene	00071-43-2	Н	Yes	Yes	95%	0.00	0.00	1.39E-05	3.47E-07	
Carbon Tetrachloride	00056-23-5	Н	Yes	Yes	95%	0.00	0.00	1.39E-05	3.47E-07	
Chlorobenzene (Monochlorobenzene)	00108-90-7	M	Yes	Yes	95%	0.00	0.00	3.47E-06	3.47E-07	
Chloroform	00067-66-3	M	Yes	Yes	95%	0.00	0.00	6.94E-06	2.77E-06	
Methyl Tert Butyl Ether	01634-04-4	M	Yes	Yes	95%	0.00	0.00	6.94E-06	3.47E-07	
Tetrachloroethylene	00127-18-4	M	Yes	Yes	95%	0.59	0.02	3.12E-03	1.17E-04	
Toluene	00108-88-3	L	Yes	Yes	95%	0.01	0.00	5.20E-05	2.43E-06	
Trichloroethylene	00079-01-6	M	Yes	Yes	95%	2.24	0.27	1.18E-02	1.43E-03	
Vinyl chloride	00075-01-4	Н	Yes	Yes	95%	0.20	0.00	1.04E-03	1.66E-05	
Xylenes	01330-20-7	M	Yes	Yes	95%	0.01	0.00	5.55E-05	6.94E-07	
Total VOCs						3.80	0.32			
Total HAPs						3.08	0.30			

Source: "GM-38 Groundwater Remedy Analysis Report", February 2003
 Source: DAR-1 AGC/SGC Tables, NYSDEC Division of Air Resources, Air Tox

3. Source: 6 NYCRR Part 200.1(cg) 4. Source: 6 NYCRR Part 200.1(ag)

ATTACHMENT C 2011 DISCHARGE GOALS AND 2011 DAR-1 ANALYSIS

Tetra Tech NUS		STANDARD CALCULATION SHEET				
CLIENT:	FILE No:	BY:	PAGE:			
US CLEAN	L Current Discharge Goals GM-38	SK CHECKED BY:	1 of 1 DATE:			
Area NWIRP Bethpage, I	9	ONEONED D1.	9/7/2011			

1. Purpose:

To calculate current discharge goals for Trichloroethene (TCE), Tetrachloroethene (PCE), Vinyl Chloride, cis 1,2-Dichloroethene, and 1,2-Dichloroethene (total), for treatment of off-gas from the air stripper stack AS-1.

2. Approach:

From the Contaminant Assessment Summary of the DAR-1 Model output for TCE, PCE, Vinyl Chloride, cis 1,2-Dichloroethene, and 1,2-Dichloroethene (total) (see DAR-1 output for analysis inputs), use the Actual Annual % of the Annual Guideline Concentration (AGC), a current average flow rate of 9,200 cubic feet per minute (cfm), and influent chemical emission rates in pounds per hour (lb/hour) and pounds per year (lb/year) to back calculate current discharge goals.

3. Calculation of Current Discharge Goals:

Chemical	Current Actual Annual % of AGC ⁽¹⁾	Current Maximum Concentration (µg/m³) ⁽²⁾	Current Chemical Emission Rate Prior to Treatment (lb/hour) ⁽³⁾	Current Chemical Emission Rate Prior to Treatment (lb/year) ⁽³⁾	Calculated Discharge Goal (lb/hr) ⁽⁴⁾	Calculated Discharge Goal (lb/year) ⁽⁴⁾	Maximum Allowable Concentration (μg/m³) ⁽⁴⁾
TCE	390.6	10,000	0.3446	3,019	0.0882	770	2,600
PCE	132.8	6,800	0.2344	2,053	0.1764	1,500	5,100
Vinyl Chloride	13.49	76	0.0026	22.94	0.0194	170	560
cis 1,2- Dichloroethene	0.2322	750	0.0258	226.4	11.13	98,000	320,000
1,2- Dichloroethene (total)	0.2322	750	0.0258	226.4	11.13	98,000	320,000

Notes:

⁽¹⁾ Actual Annual % of the AGCs is from the attached DAR-1 Model Output.

⁽²⁾Values were taken from the Quarterly Operations Report First Quarter 2011 (June 2011) from ECOR Federal Services. Values were the maximum effluent concentration in off gas from air stripper stack AS-1 for the months of January, February, and March 2011.

⁽³⁾Chemical Emission Rates were calculated from maximum concentrations and an average flow rate of 9,200 cfm.

⁽⁴⁾Discharge Goals are based on a flow of 9,200 cfm, and calculated from the Actual Annual % of the AGCs from the DAR-1 Model Output to achieve air quality requirements. The summary of additional inputs for this model run is provided in the DAR-1 Model Output. Stack height is 40 feet, and the property line was evaluated at a distance of 50 feet.

BETHPAGE SITE GM-38 OFF-SITE GROUNDWATER AIR STRIPPER STACK EMISSIONS DAR-1 MODEL OUTPUT, POINT SOURCE (STACK EMISSIONS) TYPE INCLUDES ISCLT MODELING SUMMARY

I. Summary of Inputs for Model Run to Nearest Property Line (50 feet), worst case scenario (highest contaminant concentrations seen in first quarter 2011 in untreated effluent from Air Stripper AS-1 prior to treatment with granular activated carbon (GAC))

Chemical	CAS No. 00079-01- 6 (TCE)	CAS No. 00127-18- 4 (PCE)	CAS No. 00075-01-4 (Vinyl Chloride)	CAS No. 00156-59-2 (cis 1,2- Dichloroethene)	CAS No. 00540-59-0 (1,2- Dichloroethene, total)
Emission Rate Prior to Treatment ⁽¹⁾ (lb/hour)	0.3444	0.2342	0.0026	0.0258	0.0258
Emission Rate Prior to Treatment ⁽¹⁾ (lb/year)	3,017	2,052	22.93	226.0	226.0
Maximum Concentration of Untreated Off Gas (μg/m³) ⁽¹⁾	10,000	6,800	76	750	750
Annual Guideline Concentration (AGC) (µg/m³)	0.5	1.0	0.11	63	63
Short-term Guideline Concentration (SGC) (µg/m³)	14,000	1,000	180,000		

НА	Height Above stack/ maximum height of plume (HA, feet)	15
SH	Stack Height/Treatment Building Air Stack (SH, feet)	40
D	Stack Diameter (D, inches)	36
Т	Stack Exit Temperature (T, degrees Fahrenheit)	80
V	Stack Exit Velocity (V, ft/sec)	21.69
Q ⁽²⁾	Stack Exit Flow Rate [Q, Actual Cubic Feet per Minute (ACFM)]	9,200
Dpl	Shortest Distance from Source Building (Treatment Building) to Property Line (Dpl, feet) for point sources	50
BW	Building Width (BW, feet) of Source Building (Treatment Building) for point sources	75
BL	Building Length (BL, feet) of Source Building (Treatment Building)	75
Q	Actual Hourly Emission Rate (lbs/hour) for source contaminant	Chemical specific, see above
Qa	Chemical specific, see above	

⁽¹⁾ Emission rates and maximum concentration values were taken from the Quarterly Operations Report First Quarter (June 2011) as provided by ECOR Services, using January, February, and March 2011 maximum rates of untreated off gas from Air Stripper AS-1 in the

GM-38 Treatment Building. Emission rates are based on continuous operation 24 hours per day, 7 days a week, 52 weeks a year, or approximately 8,760 hours of operation. ⁽²⁾ "Q" is an average value of January and February 2011 monthly flow rates. Effective water and vapor flow rates were reduced during the reporting period of March due to a shutdown of the Treatment Plant on March 23, 2011.

II. Contaminant Assessment Summary of TCE, PCE, Vinyl Chloride, cis 1,2-Dichloroethene, and 1,2-Dichloroethene (total):

	CONTRIBUNANT	ASSESSMENT SU	MMARY OF DAR-	ANALYSIS	9/ 8/11 Page 1
		SHORT-TERM	CULLIA	POINT or R	REA SOURCE
	ngo	FINSIMUM (Cao.Pt.Area)	OCTUBL ONNIOT	POTENTIAL ONNUAL	ONNUOT.
CAS NUMBER	µg/n3	≥ OF SGC	% OF AGC	× OF AGC	% OF AGC
00075-01-4 00079-01-6 00127-18-4	0.11000000 0.50000000 1.00000000	0.0005 0.7757 7.3852	0.0000 0.0000 0.0000	13.3889 390.1734 132.6635	13.4948 398.6266 132.8415
00156-59-2 00540-59-0	63.00000000 63.00000000	0.0000 0.0000	0.0000 0.0000	0.2320 0.2320	0.2322 0.2322
SUMMARY I	OTALS	8.1614	0.0000	536.6897	537.4274

III. Contaminant Impact Summary of TCE, PCE, Vinyl Chloride, cis 1,2-Dichloroethene, and 1,2-Dichloroethene (total):

	CONTABILA	RNT IMPACT SUM	MARY OF DAR-A	OMOTASTS.	9/ 8/11 Page 1
		SHORT-TERM	CAULTY	POINT or fi	REA SOURCE
CAS NUMBER	ndo va×e3	MOXIMUM (Gav, Pr, Ares) ug∕m3	ngTünl NMHUAL ug∕m3	POTENTIAL ONWOOD US/m3	AGTUAL AMMUAL ug∕m3
00075-01-4 00079-01-6 00127-18-4 00156-59-2 00540-59-0	0.11000000 0.50000000 1.00000000 63.00000000 63.00000000	0.81988204 108.60282900 73.85244750 8.13575172 8.13575172	0.0000000.0 0.0000000.0 0.0000000.0 0.000000	0.01472780 1.95086694 1.32663476 0.14614509 0.14614509	0.01484433 1.05313256 1.32843564 0.14630693 0.14630693

IV. Contaminant Impact Summary Step by Step Menu for TCE:

III.A.2.

III.A.3.

III.A.4.a.

```
NVIRP BETHPAGE GM-38 AREA
                                           BETHPAGE
                                                                                      OYSTER BAY, NEW
EMISSION POINT =
                                    TOTAL CAS NUMBER = 00079-01-6
                                                                                         SIC =
                                                                                                     0
    AGC =
                           0.5000000000 ug/m3
                                                             SGC =
                                                                             14000.000000 ug/m3
                       15., SH= 40., D= 36., T= 80., V= 21.69, q= 50., BW= 75., BL= 75., xCONTROL= 0.0000
   STACK: HA=
                                                                                                9200.00
BUILDING: Dpl=
** Reported Hourly Emission Rate (Q) is equal to
                                                                             0.344400000 lbs/hour.
** Reported Annual Emission Rate (Qa) is equal to 3017.000000 lbs/year.
II.B. REFINED CAUITY IMPACT METHOD (DAR-1. APPENDIX B).
                 Shortest Distance from building to Property Line (50. feet) is less than or equal to the cavity length, or 3 building heights (75. feet). Therefore, this building will have cavity impacts (if they occur) at receptors off plant property.
II.B.1.
                 The largest building dimension ( 75. feet ) is greater than or equal to the building height ( 25. feet ). Therefore, the computer will NOT redefine the cavity length.
II.B.2.
                 Stack height ( 40. feet ) is greater than cavity height ( 38. feet ). Therefore, this source does not contribute to the buildings cavity impact. The Computer will assume the CAVITY Annual Impact equals 0.00 ug/m3.
II.B.3.
II.C.
           CAUITY Annual Impact (
                                                0.000 ug/m3 ) is less than AGC
                    0.500 ug/m3 ).
III.A. STANDARD POINT SOURCE METHOD (DAR-1, APPENDIX B).
III.A.1.b.
                        Momentum flux, Fm, is equal to 1000.331 ft(4)/sec(2).
III.A.1.b.
                         Effective stack height, he, is equal to 51.001 feet.
```

STANDARD POINT SOURCE Actual Annual Impact is equal to 2.604 ug/m3 for 8760. hours/year of operation.

STANDARD POINT SOURCE Potential Annual Impact is equal

2.601 ug/m3 assuming 8,760 hours/year of operation.

Stack height to building height ratio is greater than 1.5, but less than 2.5. Computer will multiply actual annual & potential annual impacts by 0.75 factor.

III.A.5	. STANDARD POINT SOURCE Short-Term Impact is calculated below using the DAR-1 SOFTWARE PROGRAM SHORT-TERM METHOD.
1111.0.	STANDARD POINT SOURCE Actual Annual Impact (1.953 ug/md) is greater than ASC (8.50% ug/m3).
	**** Refer to DAR-1 Section III.D.1. A refined site **** specific modeling analyte may be required.
III.D.	STANDARD POINT SOURCE Potential Annual Impact (1.951 ug/m3) is greater than AGC (0.500 ug/m3).
	**** Potential Annual Impact is based upon 8760 hours/year **** **** operation instead of reported 8760. hours/year. ****
2.0	DAR-1 SOFTWARE PROGRAM SHORT-TERM METHOD. See "Technical Reference for the Screening Procedures of the DAR-1 Software Program, Wade/Sedefian,' 1/11/94.
2.2	CAVITY Short-Term Impact is equal to 0.00 ug/m3 as the plume escaped the cavity region: hs(40. feet) > hc(26. feet).
II.C.	CAUITY Short-Term Impact (0.000 ug/m3) is less than SGC (14000.000 ug/m3).

2.3	Momentum flux, Fm, is equal to 1000.331 ft(4)/sec(2).
2.3	Effective stack height, he, is equal to 51.001 feet.
2.4	Maximum non-downwash GEP stack Short-Term Impact (GSTP) is equal to 38.826 ug/m3, for hs/hb = 1.60
2.5	Maximum downwash Short-Term Impact (CSTD) is equal to 129.908 ug/m3, for: hs/hb = 1.60 and ESH = 51, feet.
2.6	Adjusted maximum downwash Short-Term (CSTD) is equal to 108.603 ug/m3, for: RF = 0.84
III.D.	Maximum non-cavity Short-Term Impact (CST: 108.603 ug/m3) is less than the SGC (14000.000 ug/m3) for the point source.
2.7	Maximum Short-Term cavity, point, or area source impact (SHORT-TERM MAXIMUM, (Cav.Pt.Area)) equals 108.603 ug/m3 and is reported in the ANALYSIS MENU. This value is less than the SGC (14000.000 ug/m3).

V. Contaminant Impact Summary Step by Step Menu for PCE:

III.A.2.

III.A.3.

```
MWIRP BETHPAGE GM-38 AREA BETHPAGE
                                                                                     OYSTER BAY, NEW
EMISSION POINT =
                                    TOTAL CAS NUMBER = 00127-18-4
                                                                                        SIC =
                                                                                                  Ø
                          1.000000000 ug/m3 SGC =
    AGC =
                                                                              1000.000000 ug/m3
                       15., SH= 40., D= 36., T= 80., U= 21.69, q= 50., BW= 75., BL= 75., xCONTROL= 0.0000
STACK: HA=
BUILDING: Dpl=
                                                                                                9200.00
** Reported Hourly Emission Rate (Q) is equal to
                                                                             0.234200000 1bs/hour.
** Reported Annual Emission Rate (Qa) is equal to 2052.000000 lbs/year.
II.B. REFINED CAUITY IMPACT METHOD (DAR-1, APPENDIX B).
                 Shortest Distance from building to Property Line (50. feet) is less than or equal to the cavity length, or 3 building heights (75. feet). Therefore, this building will have cavity impacts (if they occur) at receptors off plant property.
II.B.1.
                 The largest building dimension ( 75. feet ) is greater than or equal to the building height ( 25. feet ). Therefore, the computer will NOT redefine the cavity length.
II.B.2.
                 Stack height ( 40. feet ) is greater than cavity height ( 38. feet ). Therefore, this source does not contribute to the buildings cavity impact. The Computer will assume the CAUITY Annual Impact equals 0.00 ug/m3.
II.B.3.
II.C.
          CAUITY Annual Impact (
( 1.000 ug/m3).
                                                0.000 ug/m3 ) is less than AGC
III.A. STANDARD POINT SOURCE METHOD (DAR-1. APPENDIX B).
III.A.1.b.
                        Momentum flux, Fm, is equal to 1000.331 ft(4)/sec(2).
III.A.1.b.
                        Effective stack height, he, is equal to
                                                                                 51.001 feet.
```

STANDARD POINT SOURCE Actual Annual Impact is equal to 1.771 ug/m3 for 8762. hours/year of operation.

STANDARD POINT SOURCE Potential Annual Impact is equal to 1.769 ug/m3 assuming 8,760 hours/year of operation.

III.A.5	STANDARD POINT SOURCE Short-Term Impact is calculated below using the DAR-1 SOFTWARE PROGRAM SHORT-TERM METHOD.
111.0.	STONDORD FOINT SOURCE Noticel Roman Linguist (1.328 og/m3) is greater than AGC (1.660 og/m3).
	esse Buffer to DRB-1 Section III.D.J. R sefined site
111.D.	STANDARD POINT SOURCE Potential Annual Impact (1.327 ug/m3) is greater than AGC (1.000 ug/m3).
	**** Potential Annual Impact is based upon 8760 hours/year **** operation instead of reported 8762. hours/year. ****
2.0	DAR-1 SOFTWARE PROGRAM SHORT-TERM METHOD. See "Technical Reference for the Screening Procedures of the DAR-1 Software Program. Wade/Sedefian.' 1/11/94.
2.2	CAUITY Short-Term Impact is equal to 0.00 ug/m3 as the plume escaped the cavity region: hs(40. feet) > hc(26. feet).
11.C.	CAUITY Short-Term Impact (0.000 ug/m3) is less than SGC (1000.000 ug/m3).

2.7	Maximum Short-Term cavity, point, or area source impact (SHORT-TERM MAXIMUM, (Cav.Pt.Area)) equals 73.852 ug/m3 and is reported in the ANALYSIS MENU. This value is less than the SGC (1000.000 ug/m3).
III.D.	Maximum non-cavity Short-Term Impact (CST: 73.852 ug/m3) is less than the SGC (1000.000 ug/m3) for the point source.
2.6	Adjusted maximum downwash Short-Term (CSTD) is equal to 73.852 ug/m3, for: RF = 0.84
2.5	Maximum downwash Short-Term Impact (CSTD) is equal to 88.340 ug/m3, for: hs/hb = 1.60 and ESH = 51, feet.
2.4	Maximum non-downwash GEP stack Short-Term Impact (CSTP) is equal to 26.483 ug/m3, for hs/hb = 1.60
2.3	Effective stack height, he, is equal to 51.001 feet.
2.3	Momentum flux, Fm, is equal to 1000.331 ft(4)/sec(2).

VI. Contaminant Impact Summary Step by Step Menu for Vinyl Chloride:

```
NVIRP BETHPAGE GM-38 AREA
                                           BETHPAGE
                                                                                       OYSTER BAY, NEW
                                     TOTAL CAS NUMBER = 00075-01-4
EMISSION POINT =
                                                                                          SIC =
                                                                                                       0
                           AGC =
                       15., SH= 40., D= 36., T= 80., U= 50., BW= 75., BL= 75., ×CONTROL=
STACK: HA=
BUILDING: Dpl=
                                                                                21.69, q=
0.0000
                                                                                                   9200.00
** Reported Hourly Emission Rate (Q) is equal to
                                                                               0.002600000 1bs/hour.
** Reported Annual Emission Rate (Qa) is equal to
                                                                               22.930000 lbs/year.
II.B.
         REFINED CAUITY IMPACT METHOD (DAR-1, APPENDIX B).
                 Shortest Distance from building to Property Line ( 50. feet ) is less than or equal to the cavity length, or 3 building heights ( 75. feet ). Therefore, this building will have cavity impacts (if they occur) at receptors off plant property.
II.B.1.
                 The largest building dimension ( 75. feet ) is greater than or equal to the building height ( 25. feet ). Therefore, the computer will NOT redefine the cavity length.
II.B.2.
                 Stack height ( 40. feet ) is greater than cavity height ( 38. feet ). Therefore, this source does not contribute to the buildings cavity impact. The Computer will assume the CAUITY Annual Impact equals 0.00 ug/m3.
II.B.3.
          CAUITY Annual Impact (
( 0.110 ug/m3 ).
                                                0.000 ug/m3 ) is less than AGC
II.C.
III.A. STANDARD POINT SOURCE METHOD (DAR-1. APPENDIX B).
III.A.1.b.
                        Momentum flux, Fm, is equal to 1000.331 ft(4)/sec(2).
III.A.1.b.
                        Effective stack height, he, is equal to 51.001 feet.
III.A.2.
                 STANDARD POINT SOURCE Actual Annual Impact is equal
                             0.020 ug/m3 for 8819. hours/year of operation.
                 STANDARD POINT SOURCE Potential Annual Impact is equal to 0.020 ug/m3 assuming 8,760 hours/year of operation.
III.A.3.
                        Stack height to building height ratio is greater than 1.5, but less than 2.5. Computer will multiply actual annual & potential annual impacts by 0.75 factor.
III.A.4.a.
```

III.A.S.	STANDARD POINT SOURCE Short-Term Impact is calculated below using the DAR-1 SOFTWARE PROGRAM SHORT-TERM METHOD.
111.D.	STANDARD POINT SOURCE Actual Annual Impact (0.015 ug/m3) is less than AGC (0.110 ug/m3).
III.D.	STANDARD POINT SOURCE Potential Annual Impact (0.015 ug/m3) is less than AGC (0.110 ug/m3).
	**** Potential Annual Impact is based upon 8760 hours/year **** operation instead of reported 8819. hours/year. ****
2.0	DAR-1 SOFTWARE PROGRAM SHORT-TERM METHOD. See "Technical Reference for the Screening Procedures of the DAR-1 Software Program, Vade/Sedefian,' 1/11/94.
2.2	CAUITY Short-Term Impact is equal to 0.00 ug/m3 as the plume escaped the cavity region: hs(40. feet) > hc(26. feet).
11.C.	CAUITY Short-Term Impact (0.000 ug/m3) is less than SGC (180000.000 ug/m3).
2.3	Momentum flux, Fm, is equal to 1000.331 ft(4)/sec(2).
2.3	Effective stack height, he, is equal to 51.001 feet.
2.4	Maximum non-downwash GEP stack Short-Term Impact (CSTP) is equal to 0.293 ug/m3. for bs/bb = 1.60
2.5	Maximum downwash Short-Term Impact (CSTD) is equal to 0.981 ug/m3, for: hs/hb = 1.60 and ESH = 51. feet.
2.6	Adjusted maximum downwash Short-Term (CSTD) is equal to 0.820 ug/m3, For: RF = 0.84
111.D.	Maximum non-cavity Short-Term Impact (CST: 0.820 ug/m3) is less than the SGC (180000.000 ug/m3) for the point source.
2.7	Maximum Short-Term cavity, point, or area source impact (SHORT-TERM MAXIMUM, (Cav.Pt.Area)) equals 0.820 ug/m3 and is reported in the ANALYSIS MENU. This value is less than the SGC (180000.000 ug/m3).

VII. Contaminant Impact Summary Step by Step Menu for cis 1,2-Dichloroethene:

```
NVIRP BETHPAGE GM-38 AREA
                                             BETHPAGE
                                                                                         OYSTER BAY, NEW
EMISSION POINT =
                                      TOTAL CAS NUMBER = 00156-59-2
                                                                                            SIC = 0
    AGC =
                          63.000000000 ug/m3
                                                               SGC =
                                                                                      0.000000 ug/m3
                       15., SH= 40., D= 36., T= 80., V= 21.69, q= 50., BW= 75., BL= 75., ×CONTROL= 0.0000
    STACK: HA=
                                                                                                    9200.00
BUILDING: Dol=
** Reported Hourly Emission Rate (Q) is equal to
                                                                                0.025800000 lbs/hour.
** Reported Annual Emission Rate (Qa) is equal to
                                                                             226.000000 lbs/year.
           REFINED CAUITY IMPACT METHOD (DAR-1, APPENDIX B).
II.B.
                  Shortest Distance from building to Property Line (50. feet) is less than or equal to the cavity length, or 3 building heights (75. feet). Therefore, this building will have cavity impacts (if they occur) at receptors off plant property.
II.B.1.
                  The largest building dimension ( 75. feet ) is greater than or equal to the building height ( 25. feet ). Therefore, the computer will NOT redefine the cavity length.
II.B.2.
                  Stack height ( 40. feet ) is greater than cavity height ( 38. feet ). Therefore, this source does not contribute to the buildings cavity impact. The Computer will assume the CAUITY Annual Impact equals 0.00 ug/m3.
II.B.3.
           CAUITY Annual Impact ( 0.000 ug/m3 ) is less than AGC ( 63.000 ug/m3 ).
II.C.
III.A. STANDARD POINT SOURCE METHOD (DAR-1, APPENDIX B).
III.A.1.b.
                         Momentum flux, Fm, is equal to 1000.331 ft(4)/sec(2).
III.A.1.b.
                         Effective stack height, he, is equal to
                                                                                      51.001 feet.
                  STANDARD POINT SOURCE Actual Annual Impact is equal to 0.195 ug/m3 for 8760. hours/year of operation.
III.A.2.
III.A.3.
                  STANDARD POINT SOURCE Potential Annual Impact is equal
                             0.195 ug/m3 assuming 8,760 hours/year of operation.
                  to
                         Stack height to building height ratio is greater than 1.5, but less than 2.5. Computer will multiply actual annual & potential annual impacts by 0.75 factor.
III.A.4.a.
```

111.A.S	. STANDARD POINT SOURCE Short-Term Impact is calculated below using the DAR-1 SOFTWARE PROGRAM SHORT-TERM METHOD.
III.D.	STANDARD POINT SOURCE Actual Annual Impact (0.146 ug/m3) is less than AGC (63.000 ug/m3).
III.D.	STANDARD POINT SOURCE Potential Annual Impact (0.146 ug/m3) is less than AGC (63.000 ug/m3).
	**** Potential Annual Impact is based upon 8760 hours/year **** **** operation instead of reported 8760. hours/year. ****
2.0	DAR-1 SOFTWARE PROGRAM SHORT-TERM METHOD. See "Technical Reference for the Screening Procedures of the DAR-1 Software Program. Vade/Sedefian.' 1/11/94.
2.2	CAUITY Short-Term Impact is equal to 0.00 ug/m3 as the plume escaped the cavity region: hs(40. feet) > hc(26. feet).
II.C.	CAUITY Short-Term Impact is equal to 0.000 ug/m3. There is no SGC for this contaminant.
2.3	Momentum flux, Fm, is equal to 1000.331 ft(4)/sec(2).
2.3	Effective stack height, he, is equal to 51.001 feet.
2.4	Maximum non-downwash GEP stack Short-Term Impact (CSTP) is equal to 2.909 ug/m3. for hs/hb = 1.60
2.5	Maximum downwash Short-Term Impact (CSTD) is equal to 9.732 ug/m3. For: hs/hb = 1.60 and ESH = 51. feet.
2-6	Adjusted maximum downwash Short-Term (CSTD) is equal to 8.136 ug/m3. for: RF = 0.84
III.D.	Maximum non-cavity Short-Term Impact (CST) equals 8.136 ug/m3 for the point source. There is no SGC for this contaminant.
2.7	Maximum Short-Term cavity, point, or area source impact (SHORT-TERM MAXIMUM, (Cav.Pt.Area)) equals 8.136 ug/m3 and is reported in the ANALYSIS MENU.

VIII. Contaminant Impact Summary Step by Step Menu for 1,2-Dichloroethene (total):

NVIRP BETHPAGE GM-38 AREA OYSTER BAY, NEW BETHPAGE EMISSION POINT = CAS NUMBER = 00540-59-0 TOTAL SIC = 0 AGC = 63.0000000000 ug/m3 SGC = 0.000000 ug/m3 15., SH= 40., D= 36., T= 80., V= 50., BW= 75., BL= 75., *CONTROL= STACK: HA= 21.69, q= 0.0000 9200.00 BUILDING: Dpl= ** Reported Hourly Emission Rate (Q) is equal to 0.025800000 lbs/hour. ** Reported Annual Emission Rate (Qa) is equal to 226.000000 lbs/year. II.B. REFINED CAUITY IMPACT METHOD (DAR-1, APPENDIX B). Shortest Distance from building to Property Line (50. feet) is less than or equal to the cavity length, or 3 building heights (75. feet). Therefore, this building will have cavity impacts (if they occur) at receptors off plant property. II.B.1. The largest building dimension (75. feet) is greater than or equal to the building height (25. feet). Therefore, the computer will NOT redefine the cavity length. II_B_2_

- II.B.3. Stack height (40. feet) is greater than cavity height (38. feet). Therefore, this source does not contribute to the buildings cavity impact. The Computer will assume the CAUITY Annual Impact equals 0.00 ug/m3.

 II.C. CAUITY Annual Impact (0.000 ug/m3.) is less than AGC
- II.C. CAVITY Annual Impact (0.000 ug/m3) is less than AGC (63.000 ug/m3).
- III.A. STANDARD POINT SOURCE METHOD (DAR-1, APPENDIX B).
- III.A.1.b. Momentum flux, Fm, is equal to 1000.331 ft(4)/sec(2).
- III.A.1.b. Effective stack height, he, is equal to 51.001 feet.
- III.A.2. STANDARD POINT SOURCE Actual Annual Impact is equal to 0.195 ug/m3 for 8760. hours/year of operation.
- III.A.3. STANDARD POINT SOURCE Potential Annual Impact is equal to 0.195 ug/m3 assuming 8,760 hours/year of operation.
- III.A.4.a. Stack height to building height ratio is greater than 1.5, but less than 2.5. Computer will multiply actual annual & potential annual impacts by 0.75 factor.

- STANDARD POINT SOURCE Short-Term Impact is calculated below using the DAR-1 SOFTWARE PROGRAM SHORT-TERM METHOD. III.A.5. STANDARD POINT SOURCE Actual Annual Impact (less than AGC (63.000 ug/m3). III.D. 0.146 ug/m3) is III.D. STANDARD POINT SOURCE Potential Annual Impact (0.146 ug/m3 > is less than AGC (63.000 ug/m3). **** Potential Annual Impact is based upon 8760 hours/year **** operation instead of reported 8760. hours/year. *** **** DAR-1 SOFTWARE PROGRAM SHORT-TERM METHOD. See "Technical Reference for the Screening Procedures of the DAR-1 Software Program, Wade/Sedefian,' 1/11/94. 2.0 CAVITY Short-Term Impact is equal to 0.00 ug/m3 as the plume escaped the cavity region: hs(40. feet) > hc(26. feet). 2.2 II.C. CAUITY Short-Term Impact is equal to 0.000 ug/m3. There is no SGC for this contaminant. 1.3 Momentum flux, Fm, is equal to 1000.331 ft(4)/sec(2). Effective stack height, he, is equal to 51.001 feet. 2.3 Maximum non-downwash GEP stack Short-Term Impact (CSTP) is equal to 2.909 ug/m3. for hs/hb = 1.60 2.4 Maximum downwash Short-Term Impact (CSTD) is equal to 9.732 ug/m3, for: hs/hb = 1.60 and ESH = 51. Feet. 2.5 2.6 Adjusted maximum downwash Short-Term (CSTD) is equal 8_136 ug/m3, for: RF = Maximum non-cavity Short-Term Impact (CST) equals 8.1 for the point source. There is no SGC for this contaminant. III.D. 8.136 ug/m3
 - IX. AGCs and SGCs for TCE, PCE, Vinyl Chloride, cis 1,2-Dichloroethene, and 1,2-Dichloroethene (total):

2.7



Maximum Short-Term cavity, point, or area source impact (SHORT-TERM MAXIMUM, (Cav.Pt.Area)) equals 8.136 and is reported in the ANALYSIS MENU.

8.136 ug/m3

X. Contaminant Emissions Summary for TCE, PCE, Vinyl Chloride, cis 1,2-Dichloroethene, and 1,2-Dichloroethene (total):


	CONTAI	MINANT EMI	SSIONS SUMMARY	9/ 8/11 Page 1
ORS NUMBER	CONTRIVENANT NAME	NUM. OF EPS PER CONTAM.	EMISSIONS (lbs/hour)	EMISSIONS (lbs/year)
00075-01-4 00079-01-6	UINYL CHLORIDE TRICHEOROGYHYLENE	1	0.0026000 0.3444000	22.93000 3017.00000
00156-59-2 00540-59-0	DICHLOROETHYLENE, ci	s 1 2 1	0.2342000 0.0258000 0.0258000	226 - 00000 226 - 00000
SUMMARY	TOTALS	5	0.6328000	5543.93000

XI. Meter Grid Modeling Results for Maximum Annual Concentrations of TCE, within 25 meters:

	CONCENT	RATION AGC		18		g/m3) 00000		00079 /m3	-01-6				/08/11 :17:58
UTIVE	967888. * 966	96! 1000.	7886. 371	97: 8666.	1000. 37:	37: 2000.	9886. 37	37! 4886.	5000. 37	37 5000.	7000. 371	979 1666.	1000.
UTMN #	0.04	0.06	0.08	0.14	0.23	0.32	0.41	0.30	0.14	0.10	0.08	0.06	0.05
4510000.	0.03	0.05	0.08	0.13	0.25	0.43	0.60	0.40	0.17	0.12	0.09	0.07	0.06
45090000.	0.02	0.03	0.06	0.11	0.24	0.58	1.01	0.52	0.22	0.14	0.11	0.08	0.06
45060000.	0.02	0.03	0.04	0.06	0.18	0.62	2.16	0.64	0.31	0.19	0.13	0.11	0.09
4507000.	0.02	0.03	0.04	0.06	0.11	0.26	7.27	1.43	0.60	0.34	0.22	0.15	0.12
45060000.	0.03	0.03	0.05	0.07	0.13	0.33	2.58	2.99	1.12	0.51	0.30	0.20	0.14
4505000.	0.03	0.04	0.05	0.08	0.20	0.45	0.94	0.81	0.60	0.45	0.33	0.23	0.16
4584888.	0.03	0.04	0.07	0.12	0.20	0.22	0.47	0.43	0.33	0.27	0.24	0.20	0.16

	TRIBUTORS TO	MAXIMUM (-01-6	09/08/11 13:17:58
Enission Point	Facility No		ened)	EP	Distance to Max.(m)	.DMOD Edvgu	Percent of Max.
TOTAL	NWIRP BETHE			SSE	539.	0.727E-01	100.000
TOTAL OF ALL 1	CONTRIBUTOR	RS				0.727E-01	100.000

XII. ISCLT Model Run Information, within 25 meters:



APPENDIX C FIELD LOGS

Date: 5.30-2019



Groundwater Level Measurement Sheet

Project Site: NWIRP Bethpage - GM-38	Water Level Meter: Solinst
Location: Bethpage, NY	Weather t cloudy , 57t, 25.9" He 5mph Ess
Field Crew: RH	Time of Low Tide: N/A
	Time of High Tide: N/A

Time	Depth to Water	Total Depth of	PID	Comments
	(ft.)	Well / Screed	(ppm)	
		Interval (ft.)		
11:20	38,42	435 / 395-435		
11:10	41.71	435 / 395-435		
11:30	38. 42			
11:40	44.04	510 / 470-510		
11:45	42.47	510 / 470-510		
	42.55	510 / 470-510		
	40.19	350 / 330-350		
	43.11	495 / 475-495		
	42,41	340 / 320-340		
	44.17	495 / 475-495		
	40.13	470 / 450-470		
	37.48	470 / 450-470		
11:05		Open vault and ch	eck integrity of	piping, etc.
12:20		Open vault and ch	eck integrity of	piping, etc.
	1			
	11:20 11:10 11:30 11:40 11:45 11:50 12:10 12:20 11:55 12:00 11:00 11:25	(ft.) 11:40 38,42 11:10 41.71 11:30 38.42 11:46 44.04 11:45 42.47 11:50 42.55 12:40 40.19 12:55 42.41 11:55 42.41 11:55 42.41 12:00 40.13 11:05 0£	(ft.) Well / Screed Interval (ft.) 11:40 38:42 435 / 395-435 11:40 41.71 435 / 395-435 11:40 44:04 510 / 470-510 11:45 42.47 510 / 470-510 11:50 42.55 510 / 470-510 12:00 40.19 350 / 330-350 12:20 43:20 43:21 495 / 475-495 11:55 42.41 495 / 475-495 11:00 40.13 470 / 450-470 11:05 0 Open vault and ch	(ft.) Well / Screed (ppm) 1/20

Signature:	Date:	5.30.2019
Signature.		